

LIFT STATIONS REHABILITATION - PHASE 5 Solicitation Number: CO-00431 Job No.: 16-2502

ADDENDUM 4

June 14, 2021

To Respondent of Record:

This addendum, applicable to work referenced above, is an amendment to the price proposal, plans and specifications and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the Addendum number and issue date on the space provided in submitted copies of the Respondent Questionnaire.

RESPONSES TO QUESTIONS

 Question: Reference Spec Section 2081 – 2.04 - Metal Seated Swing Air Cushioned Check Valve. The Schedule of Manufacturers lists manufacturers and part numbers. These are also listed in part B of the Specification. Please verify if Air Cushion is required. The part numbers listed are not Air Cushion Check Valve Models.

Response: Air Cushion Check Valve will not be required.

2. Question: Reference Spec Section 2081 – 2.05 Wastewater Air/Vacuum Valves. This specification calls for Iron Body Air Valves. The Schedule of Manufactures calls for a 316SS Body. Please verify which is correct.

Response: Combination Air Release Valves and Air Release Valves shall be Stainless Steel 316 type.

	CHANGES TO THE SPECIFICATIONS
NONE	
	CHANGES TO THE PLANS
NONE	
	END OF ADDENDUM

This Addendum, including this one (1) page, is one (1) page in its entirety.

Attachments: None



Steven H. Thai, P.E. BGE, Inc. TBPE Registration No. F-1046