



2022 Water Pipeline Condition Assessment Project  
Solicitation Number: PS-00115

**ADDENDUM 1**  
**9/28/2021**

To Respondent of Record:

**CHANGES TO THE RFQ**

**1. Page 8: Section IV.C.6, Approach to Scope of Services/Project Understanding, Item b.**

Insert the following two (2) paragraphs as bulleted items to the end of this section:

- *Identify any issues the respondent may encounter in a typical water distribution system that may cause interference with the tool or technology (e.g. background noise, electrical interference, etc.). List any examples that may interfere with the resulting assessment data and/or accuracy during field assessment. List any mitigation techniques on these items.*
- *Identify any issues with data measuring and accuracy where unidentified short sections of alternative materials have been installed during previous point repairs. An example given is a short (10 ft) segment of PVC installed within a 500 ft run of DI pipe. List any mitigation techniques for this item.*

All other items shall remain.

**END OF ADDENDUM**

This Addendum is one (1) page with attachments in its entirety.