

SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: **D. Anthony Rubin**
BID NO.: 19-19060

Date Issued: May 23, 2019

**FORMAL INVITATION FOR BIDS
CONTRACT FOR THE ONE-TIME PURCHASE OF LEAK DETECTION
AND CORRELATION EQUIPMENT
ADDENDUM NO. 1**

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5th Floor, San Antonio, TX 78212 will be received until **3:00 p.m., May 29, 2019** and then publicly opened and read aloud for furnishing materials or services as described herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids
Terms and Conditions of Invitation for Bids

Specifications and General Requirements
Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name: _____ Firm Name: _____
(Please Print or Type)

Address: _____

Signature of Person Authorized to Sign Bid _____ City, State, Zip Code: _____

Email Address: _____ Telephone No.: _____

Fax No.: _____

Please complete the following:

Prompt Payment Discount: _____% _____days. (If no discount is offered, Net 30 will apply.)

Please check the following blanks which apply to your company:

Ownership of firm (51% or more):

Non-minority Hispanic African-American Other Minority (specify) _____

Female Owned Handicapped Owned Small Business (less than \$1 million annual receipts or 100 employees)

Indicate Status: Partnership Corporation Sole Proprietorship Other (specify) _____

Tax Identification Number: _____

To report suspected ethics violations impacting the San Antonio Water System, please call 1-800-687-1918.

This **Addendum no. 1** is being issued to provide responses to question submitted for bid no. 19-19060 purchase of leak detection & correlation equipment.

Approved Manufacturer:

Manufacture: Gutermann

Models: Zone Scan 820 (Item 1) and Aqua Scan TM2 (Item 2)

Question submitted for leak detection equipment bid no. 19-19060:

1. Can you tell me which specific manufacturer & model of Leak Loggers and Leak Correlator you have spec'd on this RFQ? **See above**
2. Is the end user wanting this quote as two separate kits or has one kit as they are normally provided? **Two separate kits for Item 1 and one kit for Item 2**
3. You are asking for two loggers. Do you mean (2) logger kits? **Item 1 is two separate kits that will consist of up to 20 individual correlating radio loggers. Item 2 is one kit consisting of 2 transmitting sensors.**
4. In line item #2 and #9 the output for Bluetooth. Are you discussing Bluetooth transmission between kit items or to pc? **Transmission is from kits to PC.**
5. Line item #1 be considered two correlating logger kits? **Item 1 is two separate kits that will consist of up to 20 individual correlating radio loggers.**
6. Line item #2 be considered a standalone correlator? **Yes, item 2 is a standalone correlator.**
7. Within the bid, a ground microphone is mentioned on various occasions but that piece of equipment is not listed as a line item on page 17. Is that an oversight? Do we need to plan for the ground microphone or leave that out? **Ground microphones are to be included in both Item 1 and 2.**
8. Do you require remote comms or a standard non real time correlator? **The correlating logger system should allow for the loggers to be programed completely wireless. The correlating loggers should be programmed via radio from a communication link (or similar). Noise loggers only will not be accepted.**
9. For the Esri integration is this for just location or for the inclusion of data as well? **Both location and all data.**
10. Will logger deployments be permanent or shifted through the system? **Logger deployments will be shifted through the system.**

IT IS NOT NECESSARY TO RETURN THIS ADDENDUM TOGETHER WITH YOUR BID