

SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: **D. Anthony Rubin**
BID NO.: 20-20049

Date Issued: **June 18, 2020**

**FORMAL INVITATION FOR BIDS
CONTRACT FOR THE PURCHASE OF 500HP HORIZONTAL ELECTRIC
MOTOR FOR NACO PUMP STATION
ADDENDUM NO. 1**

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5th Floor, San Antonio, TX 78212 will be received until **3:00 p.m., June 25, 2020** and then publicly opened and read aloud for furnishing materials or services as described herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids
Terms and Conditions of Invitation for Bids

Specifications and General Requirements
Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name: _____ Firm Name: _____
(Please Print or Type)

Address: _____

Signature of Person Authorized to Sign Bid _____ City, State, Zip Code: _____

Email Address: _____ Telephone No.: _____

Fax No.: _____

Please complete the following:

Prompt Payment Discount: _____% _____ days. (If no discount is offered, Net 30 will apply.)

Please check the following blanks which apply to your company:

Ownership of firm (51% or more):

Non-minority Hispanic African-American Other Minority (specify) _____

Female Owned Handicapped Owned Small Business (less than \$1 million annual receipts or 100 employees)

Indicate Status: Partnership Corporation Sole Proprietorship Other (specify) _____

Tax Identification Number: _____

To report suspected ethics violations impacting the San Antonio Water System, please call 1-800-687-1918.

This **Addendum no. 1** is being issued to provide responses and clarification to question submitted.

Page 21, last sentence under Motor Coupling is changed from:

“CONTRACTOR shall field verify the type of coupling required and coordinate with the OWNER for exact requirements.”

Is modified to read as follows:

“CONTRACTOR shall field verify the size (including keyway, shaft, etc.) of coupling required to connect to the existing pump after bid award. Provide properly sized couplings at no additional cost to SAWS. Submit coupling product data sheets for review by SAWS. Provide coupling for motor and pump; the existing motor and pump couplings will not be reused.”

Question received for Bid no. 20-20049 Purchase of 500HP Horizontal Electric Motor for Naco Pump Station

- 1. How do we go about field verifying the type of motor coupling required? Per Part 2 "Products" Motor Coupling, page 20 of 36.**

Response:

This requirement has been revised per Addendum No. 1.

- 2. In the section regarding couplings it gives a general description. Can you clarify that the existing couplings for both the motor and the pump are not to be reused?**

Response:

Please refer to Addendum No. 1 for clarification.

- 3. Can you provide the current coupling part numbers and shaft and keyway sizing for the pump if both couplings are required to be replaced?**

Response:

Please know that we do not have record documentation of the requested information. Dimensions needed by the Contractor will need to be obtained by the Contractor during the Contractor's post bid award field investigation. Please refer to Addendum No. 1 for clarification.

- 4. Does SAWS have the drawing of the existing GE's 5011LL frame motor? If you don't have the existing motor drawing, please confirm that the dimensions on the attached drawing downloaded from GE's website is correct ones.**

Response:

Please know that we do not have record documentation of the requested information. We cannot confirm the accuracy of the submitted dimensions. As described in specification Section 16406 Part 2, the Contractor is to field verify existing field conditions and obtain all field measurements necessary.

IT IS NOT NECESSARY TO RETURN THIS ADDENDUM TOGETHER WITH YOUR BID