



DPS SETTINGS

SET AT 6 P.S.I. FOR WIDE
OPERATING DIFFERENTIAL

SET AT 0 P.S.I. FOR NARROW
OPERATING DIFFERENTIAL

NOTE:
ONLY FOR VARIABLE SPEED PUMPS.

PROPERTY OF SAN ANTONIO WATER SYSTEM SAN ANTONIO, TEXAS	DIFFERENTIAL PRESSURE SWITCH DETAIL	APPROVED	REVISED
		7-14-00	
		DD-901-08	
		SHEET 3 OF 3	