



SECTION VIEW

- NOTES:**
- GASKETS FOR FLANGES SHALL BE 1/8 INCH THICK, CLOTH-INSERTED RUBBER CORROSIVE ACID AND ALKALI FREE FOR POTABLE WATER SERVICE CONFORMING TO ANSI B16.21 AND AWWA C207. FLAT FACED FLANGES SHALL REQUIRE FULL-FACE GASKETS, RAISED FACED FLANGES SHALL REQUIRE FLAT RING GASKETS.
 - PRESSURE TRANSMITTERS SHALL BE INSTALLED WITH HEAT TRACE FREEZE PROTECTION AROUND THE FLUID HOUSING OF THE INSTRUMENT AND ALL PIPING, VALVES, AND FITTINGS.

DD-905-03

SAN ANTONIO WATER SYSTEM
SAN ANTONIO, TEXAS



APPROVED:
SEPTEMBER 2012

SHEET
1 OF 1

PRESSURE REDUCING VALVE ASSEMBLY - SECTION VIEW

REVISED: