

**San Antonio Water System Material Standard Specifications**

100-10

**SPECIFICATIONS FOR PORTLAND CEMENT**

**REVISED DECEMBER 2011**

1. **SCOPE**

This specification covers Portland Cement.

2. **GENERAL REQUIREMENTS**

- a) Portland cement shall be Type I conforming to ASTM Specification C105-05, or latest revision thereof.
- b) Cement shall be furnished in moisture resistant container having a net weight of 93 pounds each.
- c) Broken bags shall not exceed two percent of the total bags in any one shipment.

**Previous Specification Date:**

FEBRUARY 2007

DECEMBER 2011