

Notification of changed conditions or potential problems.

Each user must notify the SAWS (as the control authority) promptly, in writing, of any planned substantial or significant changes to the user's operations or pretreatment system which might alter the nature, quality, or volume of its wastewater, including a change in the listed or characteristic hazardous wastes for which the user has submitted initial notification under 40 CFR 403.12 (p).

- (a) The control authority may require the user to submit such information as may be deemed necessary to evaluate the changed condition, including the submission of a wastewater discharge permit application under section 34-474(2) of the City code.
- (b) The control authority may issue a wastewater discharge permit under section 34-475 of the City code or modify an existing wastewater discharge permit under section 34-475(3) in response to changed conditions or anticipated changed conditions.
- (c) For purposes of this requirement, significant changes include, but are not limited to, flow increases of twenty (20) percent or greater, and the discharge of any previously unreported pollutants.

In the case of any discharge, including, but not limited to, accidental discharges, discharges of a nonroutine, episodic nature, a noncustomary batch discharge, or a slug load, the user shall immediately telephone and notify the RPC Department and the appropriate wastewater treatment plant of the incident. This notification shall include the location of the discharge, type of waste, concentration and volume, if known, and corrective actions taken by the user. Within five (5) days following such discharge, the user shall submit a detailed written report describing the items as referenced in sections 34-473(4) and 34-473(5) of the City code.