

Slug Control Plan (SCP)

The requirement for a SCP is listed in 40 CFR 403.8(f)(2)(vi). The minimum requirements listed must include the following elements and shall be signed and certified by the authorized representative as outlined under 30 TAC 128 and using the certification language under 30 TAC 305.44:

- A. Description of discharge practices, including non-routine batch discharges;
- B. Description of stored chemicals;
- C. Procedures for immediately notifying the POTW of slug discharges, including any discharge that would violate a prohibition under 40 CFR 403.5(b), with procedures for follow-up written notification within five (5) days;
- D. If necessary, procedures to prevent adverse impact from accidental spills, including inspection and maintenance of storage areas, handling and transfer of materials, loading and unloading operations, control of plant site run-off, worker training, building of containment structures or equipment, measures for containing toxic organic pollutants (including solvents), and/or measures and equipment for emergency response.

In addition SAWS includes specific requirements for notification in the permit language. Should a slug/accidental discharge occur, the permittee shall immediately notify the Superintendent of the Water Recycling Center that the facility discharges into.

Dos Rios [210.233.3089](#) Leon Creek WRC [210.233.3187](#) Medio Creek WRC [210.233.3933](#)

In the event that there is no answer, the permittee shall immediately notify the SAWS Emergency Operations Center at [210.233.2015](#). The permittee shall also notify the Resource Protection and Compliance Department at [210.233.3553](#) immediately if the incident occurs between 7:00 AM and 5:00 PM on workdays, or at the beginning of the first workday following the incident if otherwise. The following information shall be provided upon such notifications:

- time of the discharge;
- location of the discharge;
- type of waste;
- concentration and volume discharged;
- corrective actions initiated;
- Water Recycling Center receiving the waste.

Follow-up reporting of a Slug/Accidental discharge is required within five (5) calendar days after commencement of the discharge, the permittee shall submit to the SAWS a completed [Accidental Discharge Report Form](#) (APPENDIX C). Any necessary changes to the facilities Slug Control Plan to address a slug or an accidental discharge shall be made and submitted to the SAWS within 30 days of the discharge.