



December 30, 2013

U.S. Department of Justice  
Environmental Enforcement Section  
Environment and Natural Resources Division  
P.O. Box 7611  
Washington, D.C. 20044-7611

Via U.S. Certified Mail  
RRR# 7013 2630 0002 0130 2158

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree  
Date of Entry: October 15, 2013  
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. A copy of a five-day report submitted to TCEQ on December 30, 2013 is attached and is provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeff Haby", is written over the typed name.

Jeff Haby, P.E.

Director – Sewer System Improvements

Enc. as stated



December 30, 2013

U.S. Environmental Protection Agency, Region VI  
Chief, Water Enforcement Branch (6EN-W)  
Compliance Assurance and Enforcement Division  
1445 Ross Avenue  
Dallas, TX 75202-2733

Via U.S. Certified Mail  
RRR# 7013 2630 0002 0130 2165

U.S. Environmental Protection Agency, Region VI  
Attn: Ms. Judy Edelbrock (6EN-W)  
Environmental Protection Specialist  
Enforcement Branch  
1445 Ross Avenue  
Dallas, TX 75202-2733

Via U.S. Certified Mail  
RRR# 7013 2630 0002 0130 2165

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree  
Date of Entry: October 15, 2013  
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam: \_\_\_\_\_

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. A copy of a five-day report submitted to TCEQ on December 30, 2013 is attached and is provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeff Haby", is written over the typed name.

Jeff Haby, P.E.

Director – Sewer System Improvements

Enc. as stated

## Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation       Other

**General Information**

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permittee       Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-008-Salado Creek

**Noncompliance Summary**

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 911 Sumner Dr (FERG 192C6) Approximately 5000 gallons spilled into Alley .

SR#: 327921; INSPT#: 248886; WO#: ; Sewer Main 48478 60075

Cause of Noncompliance: Grease

Duration: Start 12/28/2013 16:23 End 12/29/2013 12:30  
(Date) (Time) (Date) (Time)

Or expected to be Corrected \_\_\_\_\_  
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

**Actions Taken**

Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<u>X</u>	no	Field Measurements
_____	yes	<u>X</u>	no	Laboratory Samples
_____	yes	<u>X</u>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Spill Contained, Returned to System, Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main,

**Verification Information**

Information Reported By Kenneth Koehler / LC/TV OPERATOR III  
(Name) (Title)

Date Reported 12/29/2013 Signature: *Jeffrey Szymanski* 12/30/13

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.