



March 7, 2014

U.S. Department of Justice
Environmental Enforcement Section
Environment and Natural Resources Division
P.O. Box 7611
Washington, D.C. 20044-7611

Via U.S. Certified Mail
RRR# 7013 2250 0001 9126 3031

Re: DOJ Case No. [90-5-1-1-09215]

Consent Decree

Date of Entry: October 15, 2013

CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on March 7, 2014 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeff Haby".

Jeff Haby, P.E.

Director – Sewer System Improvements

Enc. as stated



March 7, 2014

U.S. Environmental Protection Agency, Region VI
Chief, Water Enforcement Branch (6EN-W)
Compliance Assurance and Enforcement Division
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR# 7013 2250 0001 9126 3048

U.S. Environmental Protection Agency, Region VI
Attn: Ms. Judy Edelbrock (6EN-W)
Environmental Protection Specialist
Enforcement Branch
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR#7013 2250 0001 9126 3048

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on March 7, 2014 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeff Haby", is written over the typed name.

Jeff Haby, P.E.
Director – Sewer System Improvements

Enc. as stated

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274
 Permitte Subscriber
TCEQ Region: 13 County: Bexar Permit Number 10137-008-Salado Creek

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 1103 Crooked Arrow (Over The Edwards Aquifer Recharge Zone) (FERG 130F7) Approximately 200 gallons spilled into Drainage Culvert .

SR#: 378405 ; INSPT#: 272063; WO#: ; Sewer Main 61706 49661

Cause of Noncompliance: Debris

Duration: Start 03/04/2014 23:07 End 03/05/2014 0:30
(Date) (Time) (Date) (Time)
Or expected to be Corrected _____
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Actions Taken


Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<input checked="" type="checkbox"/>	no	Field Measurements
_____	yes	<input checked="" type="checkbox"/>	no	Laboratory Samples
_____	yes	<input checked="" type="checkbox"/>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Spill Contained, Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main,

Verification Information

Information Reported By Eric M Viera / LC/TV OPERATOR III
(Name) (Title)
Date Reported 3/5/2014 Signature:  3/6/14

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274
 Permitte Subscriber
TCEQ Region: 13 County: Bexar Permit Number: 10137-033-Dos Rios

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 302 Linda Lou Dr (FERG 231C7) Approximately 150 gallons spilled into Street .

SR#: 378125 ; INSPT#: 272003; WO#: ; Sewer Main 26182 418397

Cause of Noncompliance: Grease

Duration: Start 03/04/2014 14:45 End 03/04/2014 15:30
(Date) (Time) (Date) (Time)

Or expected to be Corrected _____
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<u>X</u>	no	Field Measurements
_____	yes	<u>X</u>	no	Laboratory Samples
_____	yes	<u>X</u>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Spill Contained, Returned to System, Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main,

Verification Information

Information Reported By Guadalupe Ortegon / LC/TV III
(Name) (Title)

Date Reported 3/4/2014 Signature: [Signature] 3/6/14

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329