



February 13, 2015

U.S. Department of Justice  
Environmental Enforcement Section  
Environment and Natural Resources Division  
P.O. Box 7611  
Washington, D.C. 20044-7611

Via U.S. Certified Mail  
RRR# 7014 1200 0001 2266 2183

Re: DOJ Case No. [90-5-1-1-09215]

Consent Decree

Date of Entry: October 15, 2013

CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on February 13, 2015 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over the typed name.

Jeffrey J. Haby, P.E.

Senior Director – Sewer System Improvements

Enc. as stated



February 13, 2015

U.S. Environmental Protection Agency, Region VI  
Chief, Water Enforcement Branch (6EN-W)  
Compliance Assurance and Enforcement Division  
1445 Ross Avenue  
Dallas, TX 75202-2733

Via U.S. Certified Mail  
RRR# 7014 1200 0001 2266 2190

U.S. Environmental Protection Agency, Region VI  
Attn: Ms. Judy Edelbrock (6EN-W)  
Environmental Protection Specialist  
Enforcement Branch  
1445 Ross Avenue  
Dallas, TX 75202-2733

Via U.S. Certified Mail  
RRR# 7014 1200 0001 2266 2190

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree  
Date of Entry: October 15, 2013  
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on February 13, 2015 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over the printed name.

Jeffrey J. Haby, P.E.  
Senior Director – Sewer System Improvements

Enc. as stated

# Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation       Other

## General Information

Entity Name: San Antonio Water System      Telephone: 210-233-3274

Permittee       Subscriber

TCEQ Region: 13      County: Bexar      Permit Number: 10137-003-Leon Creek

## Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at Pleasanton Rd 12060 (FERG 270E3) Approximately 10 gallons spilled into Ground .

SR#: 754871; INSPT#: ; WO#: 1082362; Sewer Valve 942785

Cause of Noncompliance: Structural

Duration:      Start      02/09/2015 14:30      End      02/09/2015 16:21  
(Date)      (Time)      (Date)      (Time)

Or expected to be Corrected \_\_\_\_\_  
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

## Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<input checked="" type="checkbox"/>	no	Field Measurements
_____	yes	<input checked="" type="checkbox"/>	no	Laboratory Samples
_____	yes	<input checked="" type="checkbox"/>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Spill Contained, Flushed Area With H2O, Area Cleaned and Disinfected

Actions Taken to Correct the Problem and Prevent Recurrence: Sewer Air Release Valve- Valve Was Turned Off- Work Order Created To Repair Sewer Air Release Valve

## Verification Information

Information Reported By Charles H Guzman / LC/TV III  
(Name) (Title)

Date Reported 2/9/2015      Signature: Josh [Signature] 2/12/15

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329

# Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation       Other

## General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permittee       Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-003-Leon Creek

## Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 5334 San Simeon (FERG 208E4) Approximately 40 gallons spilled into Easement.

SR#: 758598 ; INSPT#: 333069; WO#: 1083350; Sewer Main 33971 34171

Cause of Noncompliance: Structural

Duration: Start 02/11/2015 14:29 End 02/11/2015 15:30  
(Date) (Time) (Date) (Time)

Or expected to be Corrected \_\_\_\_\_  
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

## Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<input checked="" type="checkbox"/>	no	Field Measurements
_____	yes	<input checked="" type="checkbox"/>	no	Laboratory Samples
_____	yes	<input checked="" type="checkbox"/>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Spill Contained, Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main, Work Order Created To Repair Sewer Main

## Verification Information

Information Reported By Francisco M Gomez / LC/TV Operator III  
(Name) (Title)

Date Reported 2/11/2015 Signature: Josh Treast 2/12/15

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096 TCEQ Region 13 Fax: 545-4329

# Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation       Other

### General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permittee       Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-008-Salado Creek

### Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 11500 Sandman ( Edwards Aquifer Transition Zone ) (FERG 170E6) Approximately 2 gallons spilled into Drainage Culvert .

SR#: 757261 ; INSPT#: 333026; WO#: ; Sewer Main 9480 21175

Cause of Noncompliance: Debris

Duration: Start 02/10/2015 21:52 End 02/11/2015 0:30  
(Date) (Time) (Date) (Time)

Or expected to be Corrected \_\_\_\_\_  
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

### Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Field Measurements
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Laboratory Samples
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Spill Contained, Returned to System, Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main,

### Verification Information

Information Reported By Emilio Rodriguez Jr. / LC/TV Operator III  
(Name) (Title)

Date Reported 2/11/2015 Signature: Josh Trevi 2/11/15

# Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation       Other

## General Information

Entity Name: San Antonio Water System      Telephone: 210-233-3274

Permittee       Subscriber

TCEQ Region: 13      County: Bexar      Permit Number: 10137-033-Dos Rios

## Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 100 Chappie James Way (FERG 228E6) Approximately 10 gallons spilled into Street.

SR#: 754227 ; INSPT#: 332829; WO#: ; Sewer Main 565883 18312

Cause of Noncompliance: Debris

Duration:      Start      02/09/2015 10:01      End      02/09/2015 11:00  
(Date)      (Time)      (Date)      (Time)

Or expected to be Corrected \_\_\_\_\_  
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

## Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<input checked="" type="checkbox"/>	no	Field Measurements
_____	yes	<input checked="" type="checkbox"/>	no	Laboratory Samples
_____	yes	<input checked="" type="checkbox"/>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Spill Contained, Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 6 Inch Sewer Main, Unstopped Main,

## Verification Information

Information Reported By Charles H. Guzman / LC/TV III  
(Name) (Title)

Date Reported 2/9/2015      Signature: Juan Chaminey Superintendent 2-10-15

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329