



May 17, 2016

U.S. Environmental Protection Agency, Region VI
Chief, Water Enforcement Branch (6EN-W)
Compliance Assurance and Enforcement Division
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR# 7016 0340 0000 9676 6847

U.S. Environmental Protection Agency, Region VI
Attn: Ms. Judy Edelbrock (6EN-W)
Environmental Protection Specialist
Enforcement Branch
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR# 7016 0340 0000 9676 6847

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on May 17, 2016 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over the typed name.

Jeffrey J. Haby, P.E.
Vice President
Production & Treatment
Enc. as stated



May 17, 2016

U.S. Department of Justice
Environmental Enforcement Section
Environment and Natural Resources Division
P.O. Box 7611
Washington, D.C. 20044-7611

Via U.S. Certified Mail
RRR# 7016 0340 0000 9676 6854

Re: DOJ Case No. [90-5-1-1-09215]

Consent Decree

Date of Entry: October 15, 2013

CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on May 17, 2016 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over the typed name.

Jeffrey J. Haby, P.E.

Vice President

Production & Treatment

Enc. as stated

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permittee Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-008-Salado Creek

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at Holbrook 00700 (FERG 192E7) Approximately 751930 gallons spilled into Creek Bed Spilled from MH's # 47427,#46543,#47822,#990827,#48516,#47809,#47649,#60095.

SR#: 1285069; INSPT#: ; WO#: ; Sewer Manhole 47822

Cause of Noncompliance: I/I (Spilled Into Salado Creek)

| | | | | |
|-----------|-------|-------------------------|-----|-------------------------|
| Duration: | Start | <u>05/15/2016 13:37</u> | End | <u>05/16/2016 3:00</u> |
| | | (Date) (Time) | | (Date) (Time) |
| | Start | <u>05/16/2016 13:30</u> | End | <u>05/16/2016 14:40</u> |
| | | (Date) (Time) | | (Date) (Time) |
| | Start | <u></u> | End | <u></u> |
| | | (Date) (Time) | | (Date) (Time) |

Or expected to be Corrected _____ (Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers The known drinking water well owners within 1/2 mile of the spill have been notified

Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

| | | | | |
|-------|-----|----------|----|--|
| _____ | yes | <u>X</u> | no | Field Measurements |
| _____ | yes | <u>X</u> | no | Laboratory Samples |
| _____ | yes | <u>X</u> | no | Fish Kill, If yes, estimated number killed _____ |

Actions Taken to Mitigate Adverse Effects: Diluted by Heavy Rainwater

Actions Taken to Correct the Problem and Prevent Recurrence: 48 inch Main, Monitored Area. A contract For Design Has Been Awarded And The Consultant Is Proceeding With The Design.

Verification Information

Information Reported By Christopher Luna / LC/TV III
(Name) (Title)

Date Reported 5/15/2016 Signature: [Handwritten Signature]

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permitte Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-033-Dos Rios

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 417 Delmar St. (FERG 231D2) Approximately 5 gallons spilled into Ground .

SR#: 1286978 ; INSPT#: 411126; WO#: ; Sewer Main 28933 28935

Cause of Noncompliance: Debris

Duration: Start 05/16/2016 16:59 End 05/16/2016 17:40
(Date) (Time) (Date) (Time)

Or expected to be Corrected _____
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

| | | | | |
|-------|-----|-------------------------------------|----|--|
| _____ | yes | <input checked="" type="checkbox"/> | no | Field Measurements |
| _____ | yes | <input checked="" type="checkbox"/> | no | Laboratory Samples |
| _____ | yes | <input checked="" type="checkbox"/> | no | Fish Kill, If yes, estimated number killed _____ |

Actions Taken to Mitigate Adverse Effects: Spill Contained, Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main.

Verification Information

Information Reported By Ervin Martinez / LC/TV III
(Name) (Title)

Date Reported 5/16/2016 Signature: Ervin Martinez

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329

