



August 25, 2016

U.S. Environmental Protection Agency, Region VI
Chief, Water Enforcement Branch (6EN-W)
Compliance Assurance and Enforcement Division
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR #7016 0340 0000 9676 8087

U.S. Environmental Protection Agency, Region VI
Attn: Ms. Judy Edelbrock (6EN-W)
Environmental Protection Specialist
Enforcement Branch
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR #7016 0340 0000 9676 8087

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. A copy of a five-day report submitted to TCEQ on August 25, 2016 is attached and is provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over the word "Sincerely,".

Jeffrey J. Haby, P.E.
Vice President
Production & Treatment
Enc. as stated



August 25, 2016

U.S. Department of Justice
Environmental Enforcement Section
Environment and Natural Resources Division
P.O. Box 7611
Washington, D.C. 20044-7611

Via U.S. Certified Mail
RRR #7016 0340 0000 9676 8070

Re: DOJ Case No. [90-5-1-1-09215]

Consent Decree

Date of Entry: October 15, 2013

CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. A copy of a five-day report submitted to TCEQ on August 25, 2016 is attached and is provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby".

Jeffrey J. Haby, P.E.

Vice President

Production & Treatment

Enc. as stated

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other

General Information

Entity Name: San Antonio Water System Telephone No.: (210) 233-3274
 Permittee Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-008 -Salado Creek

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge):

The address of the spill was at 700 Holbrook (FERG 192-D7). An estimated volume greater than 100,000 gallons spilled into Salado Creek-spilled from multiple manholes.

SR# 1458464; INSP# ; WO# ; Sewer Main 47822 922726

Cause of Noncompliance: I/I

Spill occurred as a result of heavy rainfall in the San Antonio area.

Duration:	Start	<u>08/21/16</u>	<u>8:30</u>	End	<u>Ongoing /</u>	<u>Ongoing</u>
	(Date)	(Time)			(Date)	(Time)
	Or expected to be Corrected			<u>N/A</u>		
				(Date)		

Potential Dangers to Human Health and Safety or the Environment No Significant Dangers. No known drinking water wells within 1/2 mile of the spill.

Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<u> </u>	yes	<u> X </u>	no	Field Measurements
<u> </u>	yes	<u> X </u>	no	Laboratory Samples
<u> </u>	yes	<u> X </u>	no	Fish Kill, if yes, estimated number killed: <u> </u>

Actions Taken to Mitigate Adverse Effects: Diluted by Heavy Rainwater

Actions Taken to Correct the Problem and Prevent Recurrence: 48-Inch Sewer Main, Monitored Area SAWS plans to start replacing the sewer line early next year with a second phase to start in 2018

Verification Information

Information Reported By: Robert Rodriguez / LC/TW III
(Name) (Title)

Date Reported: 08/21/16 Signature: [Signature]

TCEQ 0501 (November 5, 2002) *If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.