



April 13, 2018

U.S. Environmental Protection Agency, Region VI  
Chief, Water Enforcement Branch (6EN-W)  
Compliance Assurance and Enforcement Division  
1445 Ross Avenue  
Dallas, TX 75202-2733

Via U.S. Certified Mail  
RRR# 7017 1000 0000 0971 6366

U.S. Environmental Protection Agency, Region VI  
Attn: Ms. Judy Edelbrock (6EN-W)  
Environmental Protection Specialist  
Enforcement Branch  
1445 Ross Avenue  
Dallas, TX 75202-2733

Via U.S. Certified Mail  
RRR# 7017 1000 0000 0971 6366

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree

Date of Entry: October 15, 2013

CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on April 13, 2018 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over the typed name.

Jeffrey J. Haby, P.E.

Vice President

Production & Treatment

Enc. as stated



April 13, 2018

U.S. Department of Justice  
Environmental Enforcement Section  
Environment and Natural Resources Division  
P.O. Box 7611  
Washington, D.C. 20044-7611

Via U.S. Certified Mail  
RRR# 7017 1000 0000 0971 6359

Re: DOJ Case No. [90-5-1-1-09215]

Consent Decree

Date of Entry: October 15, 2013

CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on April 13, 2018 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over the typed name.

Jeffrey J. Haby, P.E.

Vice President

Production & Treatment

Enc. as stated

## Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation       Other

**General Information**

Entity Name: San Antonio Water System      Telephone: 210-233-3274  
 Permittee       Subscriber  
TCEQ Region: 13      County: Bexar      Permit Number: 10137-008-Salado Creek

**Noncompliance Summary**

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 219 Ashland Dr (FERG 192E4) Approximately 39 gallons spilled into Drainage Culvert Spilled From Cleanout.

SR#: 2230404 ; INSPT#: 521019; WO#: ; Sewer Main 48391 48420  
Cause of Noncompliance: Debris

Duration: Start 04/12/2018 7:26      End 04/12/2018 8:05  
(Date)      (Time)      (Date)      (Time)  
Or expected to be Corrected \_\_\_\_\_  
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

**Actions Taken**

Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<u>X</u>	no	Field Measurements
_____	yes	<u>X</u>	no	Laboratory Samples
_____	yes	<u>X</u>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Spill Contained, Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main,

**Verification Information**

Information Reported By Richard Santos      /      LC/TV III  
(Name)      (Title)  
Date Reported 4/12/2018      Signature: Santana Mendez 4-13-18

# Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation       Other

## General Information

Entity Name: San Antonio Water System      Telephone: 210-233-3274

Permittee       Subscriber

TCEQ Region: 13      County: Bexar      Permit Number 10137-033-Dos Rios

## Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 215 Anton Dr (FERG 252B1) Approximately 500 gallons spilled into Stormdrain .

SR#: 2227810 ; INSPT#: 520928; WO#: ; Sewer Main 41997 27963

Cause of Noncompliance: Debris

Duration:      Start      04/10/2018 16:42      End      04/10/2018 17:45  
(Date)      (Time)      (Date)      (Time)

Or expected to be Corrected \_\_\_\_\_  
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

## Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<input checked="" type="checkbox"/>	no	Field Measurements
_____	yes	<input checked="" type="checkbox"/>	no	Laboratory Samples
_____	yes	<input checked="" type="checkbox"/>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Spill Contained, Returned to System, Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main,

## Verification Information

Information Reported By Richard Santos      LC/TV III  
(Name)      (Title)

Date Reported 4/10/2018      Signature:       4/12/2018

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329

# Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation       Other

## General Information

Entity Name: San Antonio Water System      Telephone: 210-233-3274

Permitte       Subscriber

TCEQ Region: 13      County: Bexar      Permit Number: 10137-033-Dos Rios

## Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 6209 West Ave - Over The Edwards Aquifer Transition Zone (FERG 190B2) Approximately 89500 gallons spilled into Creek Bed - Spilled Into Olmos Creek .

SR#: 2226704 ; INSPT#: 520899; WO#: ; Sewer Main 5312 6953

Cause of Noncompliance: Roots

Duration:      Start      04/10/2018 10:00      End      04/10/2018 16:30  
(Date)      (Time)      (Date)      (Time)

Or expected to be Corrected \_\_\_\_\_  
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers There Are No Known Drinking Water Wells Within 1/2 Mile Of The Spill.

## Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<input checked="" type="checkbox"/>	yes	<input type="checkbox"/>	no	Field Measurements
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Laboratory Samples
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Spill Contained, Clean-up Is Ongoing

Actions Taken to Correct the Problem and Prevent Recurrence: 15 Inch Sewer Main, Unstopped Main,

## Verification Information

Information Reported By Kenneth Koehler / LC/TV III  
(Name) (Title)

Date Reported 4/10/2018      Signature: *Antonia Mendez*

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system use the permit number of the treatment plant to which the collection system is tied

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329