



December 12, 2018

U.S. Department of Justice
Environmental Enforcement Section
Environment and Natural Resources Division
P.O. Box 7611
Washington, D.C. 20044-7611

Via U.S. Certified Mail
RRR# 7017 0530 0001 0087 5244

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on December 12, 2018 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over the typed name.

Jeffrey J. Haby, P.E.
Vice President
Production & Treatment
Enc. as stated



December 12, 2018

U.S. Environmental Protection Agency, Region VI
Chief, Water Enforcement Branch (6EN-W)
Compliance Assurance and Enforcement Division
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR# 7017 0530 0001 0087 5237

U.S. Environmental Protection Agency, Region VI
Attn: Ms. Judy Edelbrock (6EN-W)
Environmental Protection Specialist
Enforcement Branch
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR# 7017 0530 0001 0087 5237

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on December 12, 2018 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over the typed name.

Jeffrey J. Haby, P.E.
Vice President
Production & Treatment
Enc. as stated

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permittee Subscriber

TCEQ Region: 13 County: Bexar Permit Number 10137-003-Leon Creek

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 6606 Swiss Oaks (FERG 208B8) Approximately 1177800 gallons spilled into Creek Bed - Spilled Into Leon Creek .

SR#: 2577158; INSPT#: ; WO#: ; Sewer Main 903059 71380

Cause of Noncompliance: I/I

Duration:	Start	<u>12/07/2018 18:30</u> (Date) (Time)	End	<u>12/08/2018 5:00</u> (Date) (Time)
	Start	<u>12/08/2018 17:45</u> (Date) (Time)	End	<u>12/09/2018 3:30</u> (Date) (Time)
	Start	<u>12/09/2018 14:09</u> (Date) (Time)	End	<u>12/10/2018 5:00</u> (Date) (Time)

Or expected to be Corrected _____
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers , The One Known Drinking Water Well Owner Within 1/2 Mile Of The Spill Has Been Notified

Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<u>X</u>	no	Field Measurements
_____	yes	<u>X</u>	no	Laboratory Samples
_____	yes	<u>X</u>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Cleanup Is Ongoing

Actions Taken to Correct the Problem and Prevent Recurrence: 42 Inch Sewer Main, Monitored Area; A Project Is Currently Being Designed By An Engineering Company To Replace Pipe Immediately Downstream

Verification Information

Information Reported By Francisco Gomez LC/TV Operator II
(Name) (Title)

Date Reported 12/7/2018 Signature: [Signature] 12/11/2018

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permitte Subscriber

TCEQ Region: 13 County: Bexar Permit Number 10137-033-Dos Rios

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at Martinez Losoya 01612 (FERG 291C4) Approximately 450 gallons spilled into Ground .

SR#: 2576962; INSPT#: ; WO#: ; Sewer Lift Station 239

Cause of Noncompliance: I/I

Duration:	Start	<u>12/07/2018 15:30</u> (Date) (Time)	End	<u>12/07/2018 20:00</u> (Date) (Time)
	Start	<u>12/07/2018 21:00</u> (Date) (Time)	End	<u>12/08/2018 0:00</u> (Date) (Time)
	Start	_____ (Date) (Time)	End	_____ (Date) (Time)

Or expected to be Corrected _____

(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<u>X</u>	no	Field Measurements
_____	yes	<u>X</u>	no	Laboratory Samples
_____	yes	<u>X</u>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Site Was Cleaned And Washed, LS 239

Actions Taken to Correct the Problem and Prevent Recurrence: Monitored Area

Verification Information

Information Reported By Julian Hernandez (Name) MAINTENANCE MECHANIC (Title)

Date Reported 12/7/2018 Signature:  12/11/2018

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329