



June 28, 2019

U.S. Environmental Protection Agency, Region VI  
Chief, Water Enforcement Branch (6EN-W)  
Compliance Assurance and Enforcement Division  
1445 Ross Avenue  
Dallas, TX 75202-2733

Via U.S. Certified Mail  
RRR# 7017 0530 0001 0086 1544

U.S. Environmental Protection Agency, Region VI  
Attn: Ms. Judy Edelbrock (6EN-W)  
Environmental Protection Specialist  
Enforcement Branch  
1445 Ross Avenue  
Dallas, TX 75202-2733

Via U.S. Certified Mail  
RRR# 7017 0530 0001 0086 1544

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree  
Date of Entry: October 15, 2013  
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on June 28, 2019 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby".

Jeffrey J. Haby, P.E.  
Vice President  
Production & Treatment  
Enc. as stated



June 28, 2019

U.S. Department of Justice  
Environmental Enforcement Section  
Environment and Natural Resources Division  
P.O. Box 7611  
Washington, D.C. 20044-7611

Via U.S. Certified Mail  
RRR# 7017 0530 0001 0086 1551

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree  
Date of Entry: October 15, 2013  
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on June 28, 2019 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over the typed name.

Jeffrey J. Haby, P.E.  
Vice President  
Production & Treatment  
Enc. as stated

# Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation       Other

## General Information

Entity Name: San Antonio Water System      Telephone: 210-233-3274

Permittee       Subscriber

TCEQ Region: 13      County: Bexar      Permit Number: 10137-003-Leon Creek

## Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at Swiss Oaks 06606 - Spilled Into Leon Creek (FERG 208B8) Approximately 56500 gallons spilled into Creek Bed Leon Creek .

SR#: 2840068; INSPT#: ; WO#: 1702667; Sewer Main 903059 71380

Cause of Noncompliance: I/I

Duration:      Start      06/24/2019 17:35      End      06/25/2019 3:00  
(Date)      (Time)      (Date)      (Time)

Or expected to be Corrected \_\_\_\_\_  
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers The One Known Drinking Water Well Owner Within 1/2 Mile Of The Spill Has Been Notified

## Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<u>X</u>	no	Field Measurements
_____	yes	<u>X</u>	no	Laboratory Samples
_____	yes	<u>X</u>	no	Fish Kill, if yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Diluted By Heavy Rainwater, Cleanup Is Ongoing

Actions Taken to Correct the Problem and Prevent Recurrence: 42 Inch Sewer Main, Monitored Area. Work Order Created For Cleanup. A Project Is Currently Being Designed By An Engineering Company To Replace Pipe Immediately Downstream

## Verification Information

Information Reported By Jesse Guardiola      LC/TV II  
(Name)      (Title)

Date Reported 6/24/2019      Signature *[Handwritten Signature]* 6/25/19

TCEQ 0501 (November 5 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329

## Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation       Other

### General Information

Entity Name: San Antonio Water System      Telephone: 210-233-3274

Permitte       Subscriber

TCEQ Region: 13      County: Bexar      Permit Number: 10137-003-Leon Creek

### Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at Wrangler Dr 01618 (FERG 227E1) Approximately 135 gallons spilled into Stormdrain Spilled From M/h # 70124.

SR#: 2839810; INSPT#: ; WO#: ; Sewer Main 70124 70806

Cause of Noncompliance: Rain Event

Duration:      Start      06/24/2019 16:45      End      06/24/2019 19:00  
(Date)      (Time)      (Date)      (Time)

Or expected to be Corrected      \_\_\_\_\_  
(Date)

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

### Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

_____	yes	<u>X</u>	no	Field Measurements
_____	yes	<u>X</u>	no	Laboratory Samples
_____	yes	<u>X</u>	no	Fish Kill, If yes, estimated number killed _____

Actions Taken to Mitigate Adverse Effects: Diluted By Heavy Rainwater

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Monitored Area

### Verification Information

Information Reported By Eduardo Martinez      LC/TV III  
(Name)      (Title)

Date Reported 6/24/2019      Signature: Annette Duran      6/26/19

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329