



April 23, 2021

U.S. Department of Justice
Environmental Enforcement Section
Environment and Natural Resources Division
P.O. Box 7611
Washington, D.C. 20044-7611

Via U.S. Certified Mail
RRR# 7006 2150 0005 7541 4685

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on April 23, 2021 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby".

Jeffrey J. Haby, P.E.
Vice President
Production & Treatment
Enc. as stated



April 23, 2021

U.S. Environmental Protection Agency, Region VI
Attn: Ms. Judy Edelbrock (R6-ECDWA)
Water Enforcement Branch
U.S. EPA Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102

Via U.S. Certified Mail
RRR# 7006 2150 0005 7541 4692

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on April 23, 2021 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink that reads "Jeffrey J. Haby".

Jeffrey J. Haby, P.E.
Vice President
Production & Treatment
Enc. as stated

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Othr

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permitte Subscriber

TCEQ Region: 13 County: Bexar Permit Number 10137-033-Steven M. Clouse

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 2/1 Broadway , Approximately 4,500 Gallons Spilled Into Storm Drain - Spilled Into The San Antonio River Ferg: 211A7

Case #: 7681 / SR#: 3671805 / INSP#: 679817 / SRC: Sewer Main 3502 3525

Cause of Noncompliance: Grease

Duration: Sewer Manhole 46634 / Start 04/21/2021 10:51 / End 04/21/2021 15:00 / Hrs 4.15 / Gals 4500

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<input checked="" type="checkbox"/>	yes	<input type="checkbox"/>	no	Field Measurements
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Laboratory Samples
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Fish Kill, If yes, estimated number killed <u> </u>

Actions Taken to Mitigate Adverse Effects: Spill Contained, Cleanup Ongoing

Actions Taken to Correct the Problem and Prevent Recurrence: 12 Inch Sewer Main, Unstopped Main

Verification Information

Information Reported By Robert Rodriguez Jr / LC/TV OPERATOR II
(Name) (Title)

Date Reported 4/21/2021 Signature: Alma R. Peckett Sr. Director

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Oth

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permitte Subscriber

TCEQ Region: 13 County: Bexar Permit Number 10137-033-Steven M. Clouse

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 14/1 Cincinnati Ave, Approximately 3,100 Gallons Spilled Into River/Creek - Spilled Into Woodlawn Lake Ferg: 210A4

Case #: 7660 / SR#: 3671350 / INSP#: 679790 / SRC: Sewer Main 32355 32354

Cause of Noncompliance: Grease

Duration: Sewer Manhole 32355 / Start 04/21/2021 09:23 / End 04/21/2021 10:25 / Hrs 1.03 / Gals 3100

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<input checked="" type="checkbox"/>	yes	<input type="checkbox"/>	no	Field Measurements
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Laboratory Samples
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Fish Kill, If yes, estimated number killed <u> </u>

Actions Taken to Mitigate Adverse Effects: Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 10 Inch Sewer Main, Unstopped Main

Verification Information

Information Reported By Jacob Garza / LC/TV OPERATOR II
(Name) (Title)

Date Reported 4/21/2021 Signature:  4/22/21

Annette Duron, Director-Ops Support

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329