



November 12, 2021

U.S. Department of Justice  
Environmental Enforcement Section  
Environment and Natural Resources Division  
P.O. Box 7611  
Washington, D.C. 20044-7611

Via U.S. Certified Mail  
RRR# 7021 1970 0001 3465 7568

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree  
Date of Entry: October 15, 2013  
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on November 12, 2021 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink that reads "Jeffrey J. Haby".

Jeffrey J. Haby, P.E.  
Vice President  
Production & Treatment  
Enc. as stated



November 12, 2021

U.S. Environmental Protection Agency, Region VI  
Attn: Ms. Judy Edelbrock (R6-ECDWA)  
Water Enforcement Branch  
U.S. EPA Region 6  
1201 Elm Street, Suite 500  
Dallas, TX 75270-2102

Via U.S. Certified Mail  
RRR# 7021 1970 0001 3465 7551

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree  
Date of Entry: October 15, 2013  
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on November 12, 2021 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink that reads "Jeffrey J. Maby".

Jeffrey J. Maby, P.E.

Vice President  
Production & Treatment  
Enc. as stated

# Water Quality Noncompliance Notification REVISED

Unauthorized Discharge of Wastewater     Reportable Effluent Violation     Othr

## General Information

Entity Name: San Antonio Water System    Telephone: 210-233-3274

Permitte     Subscriber

TCEQ Region: 13    County: Bexar    Permit Number 10137-008-Salado Creek

## Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 2072 Loop 410 Se, Approximately 4,712 Gallons Spilled Into Ground Ferg: 233B3

Case #: 10280 / SR#: 3923947 / WO#: 2025070 / SRC: Sewer Main 43151 1024859

Cause of Noncompliance: Structural

Duration: Sewer Main 43151 - 1024859 / Start 11/03/2021 10:45 / End 11/09/2021 16:30 / Hrs 149.75 / Gals 4712 Estimated Gallons By Measurement

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

## Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<input checked="" type="checkbox"/>	yes	<input type="checkbox"/>	no	Field Measurements
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Laboratory Samples
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Fish Kill, If yes, estimated number killed <u>          </u>

Actions Taken to Mitigate Adverse Effects: Spill Contained, Area Cleaned and Disinfected

Actions Taken to Correct the Problem and Prevent Recurrence: 30 Inch Sewer Main, - Work Order Created To Repair Sewer Main / Project Multiple Sewershed Pkg18

## Verification Information

Information Reported By Alla Korostyshevsky / PROJECT ENGINEER  
(Name) (Title)

Date Reported 11/3/2021    Signature:     11/12/21  
Annette Duron, Director-Ops Support

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329

# Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater     Reportable Effluent Violation     Othr

## General Information

Entity Name: San Antonio Water System    Telephone: 210-233-3274

Permitte     Subscriber

TCEQ Region: 13    County: Bexar    Permit Number 10137-003-Leon Creek

## Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 2510 Darwin Dr, Approximately 4,650 Gallons Spilled Into River/Creek Dry Creek Bed Ferg: 208D2

Case #: 10300 / SR#: 3933852 / INSP#: 703408 / SRC: Sewer Main 46921 33208

Cause of Noncompliance: Grease

Duration: Sewer Manhole 33042 / Start 11/09/2021 18:42 / End 11/09/2021 20:15 / Hrs 1.55 / Gals 4650

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

## Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.


<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Field Measurements
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Laboratory Samples
<input type="checkbox"/>	yes	<input checked="" type="checkbox"/>	no	Fish Kill, If yes, estimated number killed <u>          </u>

Actions Taken to Mitigate Adverse Effects: Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main

## Verification Information

Information Reported By Emilio Rodriguez Jr / LC/TV OPERATOR III  
(Name) (Title)

Date Reported 11/9/2021    Signature:     11/12/21  
Annette Duron, Director-Ops Support

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329