



March 8, 2022

U.S. Department of Justice
Environmental Enforcement Section
Environment and Natural Resources Division
P.O. Box 7611
Washington, D.C. 20044-7611

Via U.S. Certified Mail
RRR# 7021 1970 0001 3465 8077

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on March 8, 2022 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Jeffrey J. Haby', is written over the typed name.

Jeffrey J. Haby, P.E.
Vice President
Production & Treatment
Enc. as stated



March 8, 2022

U.S. Environmental Protection Agency, Region VI
Attn: Ms. Judy Edelbrock (R6-ECDWA)
Water Enforcement Branch
U.S. EPA Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102

Via U.S. Certified Mail
RRR# 7021 1970 0001 3465 8060

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on March 8, 2022 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over the typed name and title.

Jeffrey J. Haby, P.E.
Vice President
Production & Treatment
Enc. as stated

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other _____

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274
 Permittee Subscriber
TCEQ Region: 13 County: Bexar Permit Number: 10137-033-Steven M. Clouse

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 111 Jones Ave W, Approximately 60 Gallons Spilled Into Ground , Ferg: 211b6

Case #: 11480 / SR#: 4094662 / INSP#: 722008 / SRC: Sewer Service Line 557078

Cause of Noncompliance: Grease

Duration: Sewer Service Line 557078 / Start 03/06/2022 23:30 / End 03/06/2022 23:30 / Hrs 0 / Gals 60

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Action Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Field Measurements
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Laboratory Samples
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Fish Kill, If yes, estimated number killed 0

Actions Taken to Mitigate Adverse Effects: Spill Contained, Cleanup Ongoing

Actions Taken to Correct the Problem and Prevent Recurrence: , 6-Inch Sewer Lateral, Unstopped Lower Lateral

Verification Information

Information Reported By: Richard Santos

Date Reported 3/6/2022

Signature:

Richard Santos / LC/TV OPERATOR III
JEFF HANBY
VICE PRES. PROJ.
TCEQ

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other _____

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permitte Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-003-Leon Creek

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 271 Briggs Ave, Approximately 315 Gallons Spilled Into Storm Drain , Ferg: 249d2

Case #: 11481 / SR#: 4094722 / INSP#: 722058 / SRC: Sewer Main 91667 91992

Cause of Noncompliance: Debris

Duration: Sewer Manhole 91667 / Start 03/06/2022 13:27 / End 03/06/2022 14:30 / Hrs 1.05 / Gals 315

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Action Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Field Measurements
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Laboratory Samples
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Fish Kill, If yes, estimated number killed 0

Actions Taken to Mitigate Adverse Effects: Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main

Verification Information

Information Reported By: Ervin Martinez

Date Reported 3/6/2022

Signature:

LC/TV OPERATOR III
JEFF HAYES
VICE PRES PROD

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other _____

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permittee Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-003-Leon Creek

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 7951 Sumac Rdg , Approximately 210 Gallons Spilled Into Street , Ferg: 187c2

Case #: 11500 / SR#: 4094691 / INSP#: 722049 / WO#: 2064331 / SRC: Sewer Main 62756 62778

Cause of Noncompliance: Contractor

Duration: Sewer Manhole 62756 / Start 03/06/2022 08:53 / End 03/06/2022 09:35 / Hrs .7 / Gals 210

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Action Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Field Measurements
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Laboratory Samples
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Fish Kill, If yes, estimated number killed 0


Actions Taken to Mitigate Adverse Effects: Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Repairing/Repaired Main

Verification Information

Information Reported By: Ervin Martinez

Date Reported 3/6/2022

Signature:  LC/TV OPERATOR III
JEFF HAYS
VICE PRES PROD
TJL

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.