



April 19, 2022

U.S. Department of Justice  
Environmental Enforcement Section  
Environment and Natural Resources Division  
P.O. Box 7611  
Washington, D.C. 20044-7611

Via E-mail  
[Asia.Mcneil-Womack@usdoj.gov](mailto:Asia.Mcneil-Womack@usdoj.gov)  
[Eescdcopy.enrd@usdoj.gov](mailto:Eescdcopy.enrd@usdoj.gov)  
[Mcelroy.damon@epa.gov](mailto:Mcelroy.damon@epa.gov)

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree  
Date of Entry: October 15, 2013  
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on April 19, 2022 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink, appearing to read 'Jeffrey J. Haby', is written over a light blue horizontal line.

Jeffrey J. Haby, P.E.  
Vice President  
Production & Treatment  
Enc. as stated



April 19, 2022

U.S. Environmental Protection Agency, Region VI  
Attn: Ms. Judy Edelbrock (R6-ECDWA)  
Water Enforcement Branch  
U.S. EPA Region 6  
1201 Elm Street, Suite 500  
Dallas, TX 75270-2102

Via E-Mail  
[Edelbrock.Judv@epa.gov](mailto:Edelbrock.Judv@epa.gov)  
[mcelroy.damon@epa.gov](mailto:mcelroy.damon@epa.gov)

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree  
Date of Entry: October 15, 2013  
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on April 19, 2022 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby".

Jeffrey J. Haby, P.E.  
Vice President  
Production & Treatment  
Enc. as stated

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation      Other \_\_\_\_\_

General Information

Entity Name: San Antonio Water System      Telephone: 210-233-3274  
 Permitte      Subscriber  
TCEQ Region: 13      County: Bexar      Permit Number: 10137-008-Salado Creek

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 3230 Oakleaf Dr, Approximately 415 Gallons Spilled Into Street Ferg: 192a4

Case #: 11900 / SR#: 4151127 / INSP#: 735308 / SRC: Sewer Main 88173 88445

Cause of Noncompliance: Debris

Duration: Sewer Manhole 88173 / Start 04/14/2022 08:52 / End 04/14/2022 10:15 / Hrs 1.38 / Gals 415

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Action Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Field Measurements
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Laboratory Samples
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Fish Kill, If yes, estimated number killed 0

Actions Taken to Mitigate Adverse Effects: Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main

Verification Information

Information Reported By: Cedric D Martinez      FIELD UTILITY COORDINATOR

Date Reported 4/14/2022      Signature:       4/19/22

Annette Duron, Director-Ops Support

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation      Other \_\_\_\_\_

General Information

Entity Name: San Antonio Water System      Telephone: 210-233-3274  
 Permitte      Subscriber  
TCEQ Region: 13      County: Bexar      Permit Number: 10137-003-Leon Creek

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 9115 Grissom Rd, Approximately 205 Gallons Spilled Into Storm Drain , Ferguson 187-B7

Case #: 11920 / SR#: 4154127 / INSP#: 735390 / SRC: Sewer Main 41402 41403

Cause of Noncompliance: Grease

Duration: Sewer Manhole 41402 / Start 04/15/2022 18:19 / End 04/15/2022 19:00 / Hrs .68 / Gals 205

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Action Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.


<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Field Measurements
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Laboratory Samples
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Fish Kill, If yes, estimated number killed 0

Actions Taken to Mitigate Adverse Effects: Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main

Verification Information

Information Reported By: Emilio Rodriguez Jr      LC/TV OPERATOR III

Date Reported 4/15/2022      Signature:       4/19/22  
Annette Duron, Director-Ops Support

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.