



September 30, 2022

U.S. Department of Justice
Environmental Enforcement Section
Environment and Natural Resources Division
P.O. Box 7611
Washington, D.C. 20044-7611

Via E-mail
Asia.Mcneil-Womack@usdoj.gov
Eescdcopy.enrd@usdoj.gov
Mcelroy.damon@epa.gov

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on September 30, 2022 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby", is written over a printed name.

Jeffrey J. Haby, P.E.
Vice President
Production & Treatment
Enc. as stated



September 30, 2022

U.S. Environmental Protection Agency, Region VI
Attn: Ms. Judy Edelbrock (R6-ECDWA)
Water Enforcement Branch
U.S. EPA Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102

Via E-Mail
Edelbrock.Judy@epa.gov
mcelroy.damon@epa.gov

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on September 30, 2022 are attached and are provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink that reads "Jeffrey J. Haby".

Jeffrey J. Haby, P.E.
Vice President
Production & Treatment
Enc. as stated

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other _____

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permittee Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-033-Steven M. Clouse

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 268 Menlo Blvd, Approximately 1,650 Gallons Spilled Into Street , Ferg:232a7

Case #: 13721 / SR#: 4404253 / SRC: Sewer Main 28752 28798

Cause of Noncompliance: Debris

Duration: Sewer Manhole 28752 / Start 09/26/2022 16:34 / End 09/26/2022 17:40 / Hrs 1.1 / Gals 1650

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Action Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<u> </u>	Yes	<input checked="" type="checkbox"/>	No	Field Measurements
<u> </u>	Yes	<input checked="" type="checkbox"/>	No	Laboratory Samples
<u> </u>	Yes	<input checked="" type="checkbox"/>	No	Fish Kill, If yes, estimated number killed 0

Actions Taken to Mitigate Adverse Effects: Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main

Verification Information

Information Reported By: Gino S Valdez Jr

Date Reported 9/26/2022

Signature:

[Handwritten Signature]
FOREPERSON
JEFF HARDY
VICE PRES TRT

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other _____

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permittee Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-033-Steven M. Clouse

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 7159 Old Pearsall Rd, Approximately 80,955 Gallons Spilled Into Ground , Ferg:247e6

Case #: 13722 / SR#: 4405189 / SRC: Sewer Main 40925 40926

Cause of Noncompliance: Debris

Duration: Sewer Manhole 41236 / Start 09/27/2022 09:30 / End 09/27/2022 10:45 / Hrs 1.25 / Gals 80955

Potential Dangers to Human Health and Safety or the Environment: The Known Drinking Well Owners Within 1/2 Mile Of The Spill Were Notified

Action Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<input checked="" type="checkbox"/>	Yes		No	Field Measurements
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Laboratory Samples
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Fish Kill, If yes, estimated number killed 0

Actions Taken to Mitigate Adverse Effects: Spill Contained, Cleanup Ongoing

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main

Verification Information

Information Reported By: Cedric D Martinez

FIELD UTILITY COORDINATOR

Date Reported 9/27/2022

Signature:

Jeff Harty
JEFF HARTY
VICE PRES
TKT

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

TCEQ Region 13 Phone: 490-3096

TCEQ Region 13 Fax: 545-4329

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other _____

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permittee Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-008-Salado Creek

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 9911 Grove Mist , Approximately 600 Gallons Spilled Into Street , Ferg:173b8

Case #: 13720 / SR#: 4403646 / WO#: 2183033 / SRC: Sewer Service Line 1139377

Cause of Noncompliance: Contractor

Duration: Sewer Service Line 1139377 / Start 09/26/2022 14:45 / End 09/27/2022 10:45 / Hrs 20 / Gals 600

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Action Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<u> </u>	Yes	<input checked="" type="checkbox"/>	No	Field Measurements
<u> </u>	Yes	<input checked="" type="checkbox"/>	No	Laboratory Samples
<u> </u>	Yes	<input checked="" type="checkbox"/>	No	Fish Kill, If yes, estimated number killed 0

Actions Taken to Mitigate Adverse Effects: Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: , Removed Plumbers Plug From Lower Lateral


Verification Information

Information Reported By: Elliott Desha

Date Reported 9/26/2022

Signature:

FOREPERSON JEFF HARRIS
MON
 VICE PRES TR



TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater Reportable Effluent Violation Other _____

General Information

Entity Name: San Antonio Water System Telephone: 210-233-3274

Permittee Subscriber

TCEQ Region: 13 County: Bexar Permit Number: 10137-008-Salado Creek

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 11721 Parliament , Over The Edwards Aquifer Transition Zone Approximately 635 Gallons Spilled Into Ground , Ferg:170c5

Case #: 13700 / SR#: 4402778 / SRC: Sewer Service Line 158147

Cause of Noncompliance: Grease

Duration: Sewer Service Line 158147 / Start 09/26/2022 07:53 / End 09/26/2022 10:00 / Hrs 2.12 / Gals 635

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Action Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<u> </u>	Yes	<input checked="" type="checkbox"/>	No	Field Measurements
<u> </u>	Yes	<input checked="" type="checkbox"/>	No	Laboratory Samples
<u> </u>	Yes	<input checked="" type="checkbox"/>	No	Fish Kill, If yes, estimated number killed 0

Actions Taken to Mitigate Adverse Effects: Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: Unstopped Lower Lateral

Verification Information

Information Reported By: Cedric D Martinez

Date Reported 9/26/2022

Signature: _____

FIELD UTILITY COORDINATOR
JEFF HAYN
PROJ. MGR.
VICE PRES. TILT

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.