



December 2, 2022

U.S. Department of Justice  
Environmental Enforcement Section  
Environment and Natural Resources Division  
P.O. Box 7611  
Washington, D.C. 20044-7611

Via E-mail  
[Asia.Mcneil-Womack@usdoj.gov](mailto:Asia.Mcneil-Womack@usdoj.gov)  
[Eescdcopy.enrd@usdoj.gov](mailto:Eescdcopy.enrd@usdoj.gov)  
[Mcelroy.damon@epa.gov](mailto:Mcelroy.damon@epa.gov)

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree  
Date of Entry: October 15, 2013  
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on December 2, 2022 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in black ink, appearing to read "Jeffrey J. Haby", is written over the typed name.

Jeffrey J. Haby, P.E.  
Vice President  
Production & Treatment  
Enc. as stated



December 2, 2022

U.S. Environmental Protection Agency, Region VI  
Attn: Ms. Judy Edelbrock (R6-ECDWA)  
Water Enforcement Branch  
U.S. EPA Region 6  
1201 Elm Street, Suite 500  
Dallas, TX 75270-2102

Via E-Mail  
[Edelbrock.Judy@epa.gov](mailto:Edelbrock.Judy@epa.gov)  
[mcelroy.damon@epa.gov](mailto:mcelroy.damon@epa.gov)

Re: DOJ Case No. [90-5-1-1-09215]  
Consent Decree  
Date of Entry: October 15, 2013  
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 b. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of any five-day report submitted under its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. Copies of five-day reports submitted to TCEQ on December 2, 2022 are attached and are provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in black ink, appearing to read 'Jeffrey J. Haby', is written over a large, faint watermark of the signature.

Jeffrey J. Haby, P.E.  
Vice President  
Production & Treatment  
Enc. as stated

Water Quality Noncompliance Notification

X Unauthorized Discharge of Wastewater      \_ Reportable Effluent Violation      Other \_\_\_\_\_

General Information

Entity Name: San Antonio Water System      Telephone: 210-233-3274

X Permitter      Subscriber

TCEQ Region: 13      County: Bexar      Permit Number: 10137-033-Steven M. Clouse

Noncompliance Summary

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 942 Bar Z Ranch , Approximately 1,180 Gallons Spilled Into Storm Drain , Ferg: 205-D8

Case #: 14245 / SR#: 4504735 / SRC: Sewer Main 488445 488446

Cause of Noncompliance: Grease

Duration: Sewer Manhole 488445 / Start 12/01/2022 08:17 / End 12/01/2022 10:15 / Hrs 1.97 / Gals 1180

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

Action Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

—	Yes	X	No	Field Measurements
—	Yes	X	No	Laboratory Samples
—	Yes	X	No	Fish Kill, If yes, estimated number killed 0

Actions Taken to Mitigate Adverse Effects: Spill Contained, Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main

Verification Information

Information Reported By: Cedric D Martinez

Date Reported 12/1/2022

Signature:

FIELD UTILITY COORDINATOR  
JEFF HEARD  
VICE PRES PROJ  
T.M.

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation      Other \_\_\_\_\_

**General Information**

Entity Name: San Antonio Water System      Telephone: 210-233-3274  
 Permittee      Subscriber  
TCEQ Region: 13      County: Bexar      Permit Number: 10137-008-Salado Creek

**Noncompliance Summary**

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 3627 Booker Trl, Approximately 101 Gallons Spilled Into Drainage Channel , Ferg: 252-D4

Case #: 14242 / SR#: 4501168 / INSP#: 753729 / SRC: Sewer Main 1059153 1059152

Cause of Noncompliance: Contractor

Duration: Sewer Manhole 1059153 / Start 11/29/2022 20:49 / End 11/29/2022 22:30 / Hrs 1.68 / Gals 101

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

**Action Taken**

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<input checked="" type="checkbox"/>	Yes		No	Field Measurements
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Laboratory Samples
<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	No	Fish Kill, If yes, estimated number killed 0

Actions Taken to Mitigate Adverse Effects: Area Cleaned and Disinfected, Flushed Area with H2O

Actions Taken to Correct the Problem and Prevent Recurrence: 8 Inch Sewer Main, Unstopped Main

**Verification Information**

Information Reported By: Eric M Viera

Date Reported 11/29/2022

Signature: \_\_\_\_\_

LC/TV OPERATOR III  
JEFF HADY  
VICE PRES PRODU  
TRT.

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.

Water Quality Noncompliance Notification

Unauthorized Discharge of Wastewater       Reportable Effluent Violation      Other \_\_\_\_\_

**General Information**

Entity Name: San Antonio Water System      Telephone: 210-233-3274  
 Permittee      Subscriber  
TCEQ Region: 13      County: Bexar      Permit Number: 10137-008-Salado Creek

**Noncompliance Summary**

Description of Noncompliance (include location, discharge route, and estimated volume if an unauthorized discharge): The address of the spill was at 13515 West Ave, Over The Edwards Aquifer Transition Zone Approximately 600 Gallons Spilled Into Storm Drain , Ferg: 170-F3

Case #: 14243 / SR#: 4502410 / INSP#: 753795 / SRC: Sewer Main 66777 51773

Cause of Noncompliance: Debris

Duration: Sewer Manhole 66776 / Start 11/30/2022 08:30 / End 11/30/2022 13:30 / Hrs 5 / Gals 300  
Sewer Manhole 66777 / Start 11/30/2022 08:30 / End 11/30/2022 13:30 / Hrs 5 / Gals 300

Potential Dangers to Human Health and Safety or the Environment: No Significant Dangers

**Action Taken**

Monitoring Data: Data should be attached or submitted to TCEQ when available.

<u>  </u>	Yes	<input checked="" type="checkbox"/>	No	Field Measurements
<u>  </u>	Yes	<input checked="" type="checkbox"/>	No	Laboratory Samples
<u>  </u>	Yes	<input checked="" type="checkbox"/>	No	Fish Kill, If yes, estimated number killed 0


Actions Taken to Mitigate Adverse Effects: Spill Contained, Cleanup Ongoing

Actions Taken to Correct the Problem and Prevent Recurrence: 10 Inch Sewer Main, Unstopped Main

**Verification Information**

Information Reported By: Cedric D Martinez

Date Reported 11/30/2022

Signature:       JEFF HABY  
VICE PRES MODK  
TOL  
FIELD UTILITY COORDINATOR

TCEQ 0501 (November 5, 2002) If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied.