



May 15, 2017

U.S. Department of Justice
Environmental Enforcement Section
Environment and Natural Resources Division
P.O. Box 7611
Washington, D.C. 20044-7611

Via U.S. Certified Mail
RRR# 7014 1200 0001 2267 2311

Re: DOJ Case No. [90-5-1-1-09215]

Consent Decree

Date of Lodging: July 23, 2013

Date of Entry: October 15, 2013

CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 a. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of the monthly compliance report required by its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. A copy of the monthly compliance report for April 2017 is attached and is provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink that reads "Jeffrey J. Haby".

Jeffrey J. Haby, P.E.

Vice President – Production & Treatment

Enc. As stated



May 15, 2017

U.S. Environmental Protection Agency, Region VI
Chief, Water Enforcement Branch (6EN-W)
Compliance Assurance and Enforcement Division
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR #7014 1200 0001 2267 2328

U.S. Environmental Protection Agency, Region VI
Attn: Ms. Judy Edelbrock (6EN-W)
Environmental Protection Specialist
Enforcement Branch
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR #7014 1200 0001 2267 2328

Re: DOJ Case No. [90-5-1-1-09215]
Consent Decree
Date of Lodging: July 23, 2013
Date of Entry: October 15, 2013
CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 a. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of the monthly compliance report required by its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. A copy of the monthly compliance report for April 2017 is attached and is provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby".

Jeffrey J. Haby, P.E.

Vice President – Production & Treatment

Enc. As stated

OVERFLOW REPORT

PERIOD: APRIL 2017

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments	
	480150	1760203	4/25/2017	Carroll Ave	203	50	Grease	Cleaned Main	1.70	1.70	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
1397512	480035	1758047	4/24/2017	Mozart Ave	2922	4,325	Structural	Cleaned Main	7.60	0.85	Drainage Culvert	Work Order Created To Repair Sewer Main - Clean-up Is Ongoing
	480030	1757524	4/24/2017	Big Foot	725	25	Debris	Cleaned Main	1.70	1.53	Street	Area Cleaned and Disinfected, Flushed Area with H2O
	479255	1745568	4/15/2017	San Francisco St	1403	1,100	Debris	Cleaned Main	0.25	0.00	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
	479015	1740463	4/11/2017	Heame	119	50	Grease	Cleaned Main	1.93	1.10	Street	Area Cleaned and Disinfected, Flushed Area with H2O
	478998	1740303	4/11/2017	Hackberry St S	3300	6,000	Grease	Cleaned Main	0.67	0.50	Street	Area Cleaned and Disinfected, Flushed Area with H2O
	478945	1737420	4/10/2017	Dewhurst Rd	7235	79	Contractor	Repaired Lateral	1.32	0.57	Ground	Area Cleaned and Disinfected, Flushed Area with H2O Contractor Will Be Making Repairs To 6 Inch Lateral
	478588	1732731	4/5/2017	Barefield Dr	2200	1	Grease	Cleaned Main	2.28	0.12	Ground - Over The Edwards Aquifer Transition Zone	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:		8	Total Gallons:		11,630	Average Duration:		2.18	0.80	Average Response		

Tuesday, May 02, 2017

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: APRIL 2017

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments	
	479563	1748840	4/18/2017	West Ave	11802	4,800	Debris	Cleaned Main	0.80	0.52	Street - Over The Edwards Aquifer Transition Zone	Area Cleaned and Disinfected, Flushed Area with H2O
1392605	479054	1740477	4/11/2017	Brook Hollow Blvd	14303	1,880	Contractor	Repaired Main	3.13	0.63	Drainage Culvert - Over The Edwards Aquifer Recharge Zone	Work Order Created To Repair Sewer Main - Cleanup Is Ongoing
Total Events:		2	Total Gallons:			6,680	Average Duration:		1.97	0.58	Average Response	

Tuesday, May 02, 2017

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD:

WATERSHED: SUBSCRIBER

TCEQ PERMIT # Subscriber

EPA PERMIT # Subscriber

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Average Duration:			Average Response		

Tuesday, May 02, 2017

Note: Comments reflect status reported on the 5-Day report

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
 NAME: DOS RIOS WATER RECYLING CENTER
 ADDRESS: 3495 VALLEY RD
 SAN ANTONIO, TX 78221
 FACILITY: DOS RIOS WATER RECYCLING CTR.
 LOCATION: 3495 VALLEY RD.
 SAN ANTONIO, TX 78221
 ATTN: PARVIZ CHAVOL SR DIR

TX0077801	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
 MAJOR
 (SUBR 13)
 DOMESTIC FACILITY - 001
 External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****	7.10	*****	*****		0	1/Day	
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6 MO MIN	*****	*****	mg/L		Daily	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.80	*****	7.20		0	1/Day	
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6 MINIMUM	*****	9 MAXIMUM	SU		Daily	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	1,153	*****		*****	1.51	2.70		0	1/Day	
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	12510 DAILY AV	*****	lb/d	*****	12 DAILY AV	40 DAILY MX	mg/L		Daily	COMPOS
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	318	*****		*****	0.42	1.68		0	1/Day	
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	2085 DAILY AV	*****	lb/d	*****	2 DAILY AV	7 DAILY MX	mg/L		Daily	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	92.36	105.47		*****	*****	*****	*****	0	Continuous	
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	*****	97,662		*****	*****	*****	*****	0	Continuous	
50050 P 0 See Comments	PERMIT REQUIREMENT	*****	173611 2HR PEAK	gal/min	*****	*****	*****	*****		Monthly	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	97.16	*****		*****	*****	*****	*****	0	Continuous	
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	125 ANNL AVG	*****	MGD	*****	*****	*****	*****		Continuous	TOTALZ

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
Parviz Chavol Sr. Dir		(210) 233-3239	5/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 ANNUAL AVERAGE FLOW SHALL NOT EXCEED 125 MGD. SEE OTHER REQUIREMENTS NO. 7 ON PAGE 36.

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: DOS RIOS WATER RECYLING CENTER
ADDRESS: 3495 VALLEY RD
 SAN ANTONIO, TX 78221
FACILITY: DOS RIOS WATER RECYCLING CTR.
LOCATION: 3495 VALLEY RD.
 SAN ANTONIO, TX 78221
ATTN: PARVIZ CHAVOL SR DIR

TX0077801	001- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
 MAJOR
 (SUBR 13)
 DOMESTIC FACILITY - 001
 External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chlorine, total residual 50060 A 0 Disinfection, Process Complete	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0.07		0	1/Day	
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	.1 INST MAX	mg/L		Daily	GRAB
Chlorine, total residual 50060 B 0 Prior to Disinfection	SAMPLE MEASUREMENT	*****	*****	*****	1.14	*****	*****		0	1/Day	
	PERMIT REQUIREMENT	*****	*****	*****	1 MO MIN	*****	*****	mg/L		Daily	GRAB
E. coli 51040 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.12	4.00		0	5/week	
	PERMIT REQUIREMENT	*****	*****	*****	*****	126 DAILY AV	399 DAILY MX	CFU/100 mL		Five per Week	GRAB
BOD, carbonaceous [5 day, 20 C] 80082 1 0 Effluent Gross	SAMPLE MEASUREMENT	1,541	*****		*****	2.00	2.00		0	1/Day	
	PERMIT REQUIREMENT	5213 DAILY AV	*****	lb/d	*****	5 DAILY AV	20 DAILY MX	mg/L		Daily	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Parviz Chavol Sr. Dir	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
			(210) 233-3239	05/11/2017	AREA Code
TYPED OR PRINTED					

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 ANNUAL AVERAGE FLOW SHALL NOT EXCEED 125 MGD. SEE OTHER REQUIREMENTS NO. 7 ON PAGE 36.

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: DOS RIOS WATER RECYLING CENTER
 ADDRESS: 3495 VALLEY RD
 SAN ANTONIO, TX 78221
 FACILITY: DOS RIOS WATER RECYCLING CTR.
 LOCATION: 3495 VALLEY RD.
 SAN ANTONIO, TX 78221
 ATTN: PARVIZ CHAVOL SR DIR

TX0077801	002- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
 MAJOR
 (SUBR 13)
 DOMESTIC FACILITY - 002
 External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****	6.90	*****	*****		0	1/day	
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	4 MO MIN	*****	*****	mg/L		Daily	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.20	*****	7.70		0	1/day	
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	9 MAXIMUM	SU		Daily	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	39.96	*****		*****	1.53	2.70		0	1/Day	
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	1251 DAILY AV	*****	lb/d	*****	15 DAILY AV	40 DAILY MX	mg/L		Daily	COMPOS
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	11.88	*****		*****	0.43	1.68		0	1/Day	
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	167 DAILY AV	*****	lb/d	*****	2 DAILY AV	7 DAILY MX	mg/L		Daily	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	3.17	5.00		*****	*****	*****	*****	0	Continuous	
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	3.61	*****		*****	*****	*****	*****	0	Continuous	
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	10 ANNL AVG	*****	MGD	*****	*****	*****	*****		Monthly	TOTALZ
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0.05		0	Continuous	
50060 A 0 Disinfection, Process Complete	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	.1 INST MAX	mg/L		Daily	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
Parviz Chavol Sr. Dir		(210) 233-3239	05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 SEE OTHER REQUIREMENTS NO.7 ON PAGE 36.

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: DOS RIOS WATER RECYLING CENTER
 ADDRESS: 3495 VALLEY RD
 SAN ANTONIO, TX 78221
 FACILITY: DOS RIOS WATER RECYCLING CTR.
 LOCATION: 3495 VALLEY RD.
 SAN ANTONIO, TX 78221


TX0077801	002- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
 MAJOR (SUBR 13)
 DOMESTIC FACILITY - 002
 External Outfall

No Discharge

ATTN: PARVIZ CHAVOL SR DIR

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chlorine, total residual 50060 B 0 Prior to Disinfection	SAMPLE MEASUREMENT	*****	*****	*****	1.14	*****	*****		0	1/day	
	PERMIT REQUIREMENT	*****	*****	*****	1 MO MIN	*****	*****	mg/L		Daily	GRAB
E. coli 51040 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.13	4.00		0	5/week	
	PERMIT REQUIREMENT	*****	*****	*****	*****	63 DAILY AV	399 DAILY MX	CFU/100 mL		Three per Week	GRAB
BOD, carbonaceous [5 day, 20 C] 80082 1 0 Effluent Gross	SAMPLE MEASUREMENT	52.79	*****		*****	2.00	2.00		0	Daily	
	PERMIT REQUIREMENT	834 DAILY AV	*****	lb/d	*****	10 DAILY AV	25 DAILY MX	mg/L		Daily	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Parviz Chavol Sr. Dir	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
			(210) 233-3239		05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SEE OTHER REQUIREMENTS NO.7 ON PAGE 36.

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: DOS RIOS WATER RECYLING CENTER

ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221

FACILITY: DOS RIOS WATER RECYCLING CTR.

LOCATION: 3495 VALLEY RD.
SAN ANTONIO, TX 78221

ATTN: PARVIZ CHAVOL SR DIR

TX0077801	003- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
MAJOR (SUBR 13)
DOMESTIC FACILITY - 003
External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****		*****	*****				
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	4 MO MIN	*****	*****	mg/L		Daily	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6 MINIMUM	*****	9 MAXIMUM	SU		Daily	GRAB
Solids, total suspended	SAMPLE MEASUREMENT		*****		*****						
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	1251 DAILY AV	*****	lb/d	*****	15 DAILY AV	40 DAILY MX	mg/L		Daily	COMPOS
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT		*****		*****						
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	167 DAILY AV	*****	lb/d	*****	2 DAILY AV	7 DAILY MX	mg/L		Daily	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT				*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT		*****		*****	*****	*****	*****			
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	10 ANNL AVG	*****	MGD	*****	*****	*****	*****		Monthly	TOTALZ
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****					
50060 A 0 Disinfection, Process Complete	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	.1 INST MAX	mg/L		Daily	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
		(210) 233-3239	05/11/2017
TYPED OR PRINTED		AREA Code	NUMBER
Parviz Chavol Sr. Dir			
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SEE OTHER REQUIREMENTS NO.7 ON PAGE 36.

NO DISCHARGE

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: DOS RIOS WATER RECYLING CENTER
ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221
FACILITY: DOS RIOS WATER RECYCLING CTR.
LOCATION: 3495 VALLEY RD.
SAN ANTONIO, TX 78221
ATTN: PARVIZ CHAVOL SR DIR

TX0077801	003- A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
MAJOR (SUBR 13)
DOMESTIC FACILITY - 003
External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chlorine, total residual 50060 B 0 Prior to Disinfection	SAMPLE MEASUREMENT	*****	*****	*****		*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	1 MO MIN	*****	*****	mg/L		Daily	GRAB
E. coli 51040 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****	63 DAILY AV	399 DAILY MX	CFU/100 mL		Three per Week	GRAB
BOD, carbonaceous [5 day, 20 C] 80082 1 0 Effluent Gross	SAMPLE MEASUREMENT		*****		*****						
	PERMIT REQUIREMENT	834 DAILY AV	*****	lb/d	*****	10 DAILY AV	25 DAILY MX	mg/L		Daily	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
Parviz Chavol Sr. Dir		(210) 233-3239		05/11/2017	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SEE OTHER REQUIREMENTS NO.7 ON PAGE 36.

NO DISCHARGE

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: DOS RIOS WATER RECYLING CENTER

ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221

FACILITY: DOS RIOS WATER RECYCLING CTR.

LOCATION: 3495 VALLEY RD.
SAN ANTONIO, TX 78221

ATTN: PARVIZ CHAVOL SR DIR

TX0077801	004- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221

MAJOR

(SUBR 13)

DOMESTIC FACILITY - 004

External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****	7.70	*****	*****		0	1/day	
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	5 MO MIN	*****	*****	mg/L		Daily	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.50	*****	7.80		0	1/day	
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	9 MAXIMUM	SU		Daily	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	5.76	*****		*****	1.53	2.40		0	1/Day	
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	375 DAILY AV	*****	lb/d	*****	15 DAILY AV	40 DAILY MX	mg/L		Daily	COMPOS
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	2.18	*****		*****	0.58	1.68		0	1/Day	
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	50 DAILY AV	*****	lb/d	*****	2 DAILY AV	7 DAILY MX	mg/L		Daily	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.44	0.60		*****	*****	*****	*****	0	Continuous	
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.46	*****		*****	*****	*****	*****	0	Continuous	
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	3 ANNL AVG	*****	MGD	*****	*****	*****	*****		Monthly	TOTALZ
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0.04		0	1/day	
50060 A 0 Disinfection, Process Complete	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	.1 INST MAX	mg/L		Daily	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
Parviz Chavol Sr. Dir		(210) 233-3239	05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SEE OTHER REQUIREMENTS NO.7 ON PAGE 36..

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: DOS RIOS WATER RECYLING CENTER
 ADDRESS: 3495 VALLEY RD
 SAN ANTONIO, TX 78221
 FACILITY: DOS RIOS WATER RECYCLING CTR.
 LOCATION: 3495 VALLEY RD.
 SAN ANTONIO, TX 78221


TX0077801	004- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
 MAJOR (SUBR 13)
 DOMESTIC FACILITY - 004
 External Outfall

No Discharge

ATTN: PARVIZ CHAVOL SR DIR

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chlorine, total residual 50060 B 0 Prior to Disinfection	SAMPLE MEASUREMENT	*****	*****	*****	1.14	*****	*****		0	1/day	
	PERMIT REQUIREMENT	*****	*****	*****	1 MO MIN	*****	*****	mg/L		Daily	GRAB
E. coli 51040 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.19	4.00		0	5/week	
	PERMIT REQUIREMENT	*****	*****	*****	*****	63 DAILY AV	399 DAILY MX	CFU/100 mL		Weekly	GRAB
BOD, carbonaceous [5 day, 20 C] 80082 1 0 Effluent Gross	SAMPLE MEASUREMENT	7.28	*****		*****	2.00	2.00		0	1/Day	
	PERMIT REQUIREMENT	250 DAILY AV	*****	lb/d	*****	10 DAILY AV	25 DAILY MX	mg/L		Daily	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Parviz Chavol Sr. Dir TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE	
			(210) 233-3239		05/11/2017	
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 SEE OTHER REQUIREMENTS NO.7 ON PAGE 36..

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: DOS RIOS WATER RECYLING CENTER
 ADDRESS: 3495 VALLEY RD
 SAN ANTONIO, TX 78221
 FACILITY: DOS RIOS WATER RECYCLING CTR.
 LOCATION: 3495 VALLEY RD.
 SAN ANTONIO, TX 78221


TX0077801	005- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
 MAJOR (SUBR 13)
 DOMESTIC FACILITY - 005
 External Outfall

No Discharge

ATTN: PARVIZ CHAVOL SR DIR

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****	6.70	*****	*****		0	1/day	
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	4 MO MIN	*****	*****	mg/L		Daily	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.00	*****	7.50		0	1/day	
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6 MINIMUM	*****	9 MAXIMUM	SU		Daily	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	7.09	*****		*****	1.53	2.70		0	1/Day	
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	325 DAILY AV	*****	lb/d	*****	15 DAILY AV	40 DAILY MX	mg/L		Daily	COMPOS
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	2.02	*****		*****	0.43	1.68		0	1/Day	
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	43 DAILY AV	*****	lb/d	*****	2 DAILY AV	7 DAILY MX	mg/L		Daily	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.55	0.63		*****	*****	*****	*****	0	Continuous	
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.63	*****		*****	*****	*****	*****	0	Continuous	
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	2.6 ANNL AVG	*****	MGD	*****	*****	*****	*****		Monthly	TOTALZ
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0.06		0	1/day	
50060 A 0 Disinfection, Process Complete	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	.1 INST MAX	mg/L		Daily	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Parviz Chavol Sr. Dir	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
			(210) 233-3239		05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 SEE OTHER REQUIREMENTS NO.7 ON PAGE 36.

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: DOS RIOS WATER RECYLING CENTER

ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221

FACILITY: DOS RIOS WATER RECYCLING CTR.

LOCATION: 3495 VALLEY RD.
SAN ANTONIO, TX 78221


ATTN: PARVIZ CHAVOL SR DIR

TX0077801	005- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
MAJOR
(SUBR 13)
DOMESTIC FACILITY - 005
External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chlorine, total residual 50060 B 0 Prior to Disinfection	SAMPLE MEASUREMENT	*****	*****	*****	1.14	*****	*****		0	1/day	
	PERMIT REQUIREMENT	*****	*****	*****	1 MO MIN	*****	*****	mg/L		Daily	GRAB
E. coli 51040 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.13	4.00		0	5/week	
	PERMIT REQUIREMENT	*****	*****	*****	*****	63 DAILY AV	399 DAILY MX	CFU/100 mL		Weekly	GRAB
BOD, carbonaceous [5 day, 20 C] 80082 1 0 Effluent Gross	SAMPLE MEASUREMENT	9.23	*****		*****	2.00	2.00		0	1/Day	
	PERMIT REQUIREMENT	217 DAILY AV	*****	lb/d	*****	10 DAILY AV	25 DAILY MX	mg/L		Daily	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Parviz Chavol Sr. Dir	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
			(210) 233-3239		05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SEE OTHER REQUIREMENTS NO.7 ON PAGE 36.

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
 NAME: DOS RIOS WATER RECYLING CENTER
 ADDRESS: 3495 VALLEY RD
 SAN ANTONIO, TX 78221
 FACILITY: DOS RIOS WATER RECYCLING CTR.
 LOCATION: 3495 VALLEY RD.
 SAN ANTONIO, TX 78221
 ATTN: PARVIZ CHAVOL SR DIR

TX0077801	006- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
 MAJOR
 (SUBR 13)
 DOMESTIC FACILITY - 006
 External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****		*****	*****				
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	4 MO MIN	*****	*****	mg/L		Daily	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	9 MAXIMUM	SU		Daily	GRAB
Solids, total suspended	SAMPLE MEASUREMENT		*****		*****						
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	5755 DAILY AV	*****	lb/d	*****	15 DAILY AV	40 DAILY MX	mg/L		Daily	COMPOS
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT		*****		*****						
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	767 DAILY AV	*****	lb/d	*****	2 DAILY AV	7 DAILY MX	mg/L		Daily	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT				*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT		*****		*****	*****	*****	*****			
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	46 ANNL AVG	*****	MGD	*****	*****	*****	*****		Monthly	TOTALZ
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****					
50060 A 0 Disinfection, Process Complete	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	.1 INST MAX	mg/L		Daily	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
Parviz Chavol Sr. Dir		(210) 233-3239	05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 SEE OTHER REQUIREMENTS NO.7 ON PAGE 36.
 NO DISCHARGE

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: DOS RIOS WATER RECYLING CENTER
 ADDRESS: 3495 VALLEY RD
 SAN ANTONIO, TX 78221
 FACILITY: DOS RIOS WATER RECYCLING CTR.
 LOCATION: 3495 VALLEY RD.
 SAN ANTONIO, TX 78221

TX0077801	006- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
 MAJOR
 (SUBR 13)
 DOMESTIC FACILITY - 006
 External Outfall

No Discharge

ATTN: PARVIZ CHAVOL SR DIR

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****		*****	*****				
50060 B 0 Prior to Disinfection	PERMIT REQUIREMENT	*****	*****	*****	1 MO MIN	*****	*****	mg/L		Daily	GRAB
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****						
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	63 DAILY AV	399 DAILY MX	CFU/100 mL		Five per Week	GRAB
BOD, carbonaceous [5 day, 20 C]	SAMPLE MEASUREMENT		*****		*****						
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	3836 DAILY AV	*****	lb/d	*****	10 DAILY AV	25 DAILY MX	mg/L		Daily	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
Parviz Chavol Sr. Dir		(210) 233-3239	05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SEE OTHER REQUIREMENTS NO.7 ON PAGE 36.

NO DISCHARGE

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: DOS RIOS WATER RECYLING CENTER
ADDRESS: 3495 VALLEY RD
 SAN ANTONIO, TX 78221
FACILITY: DOS RIOS WATER RECYCLING CTR.
LOCATION: 3495 VALLEY RD.
 SAN ANTONIO, TX 78221
ATTN: PARVIZ CHAVOL SR DIR

TX0077801	101-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
 MAJOR
 (SUBR 13)
 DOMESTIC WASTEWATER - 101
 Internal Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	6.21	7.88		*****	*****	*****	*****	0	Continuous	
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	5.43	*****		*****	*****	*****	*****	0	Continuous	
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	Req. Mon. ANNL AVG	*****	MGD	*****	*****	*****	*****		Continuous	TOTALZ

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
Parviz Chavol Sr. Dir			(210) 233-3239	05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

WASTEWATER CONTRIBUTIONS FROM THE DOS RIOS WATER RECYCLING CENTER TO THE REUSE WATER SYSTEM SHALL BE MONITORED FOR FLOW AFTER CHLORINATION AT THE RECYCLED WATER PUMP AND REPORTED AS OUTFALL 101.

DISCHARGE MONITORING REPORT (DMR)


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: DOS RIOS WATER RECYLING CENTER
 ADDRESS: 3495 VALLEY RD
 SAN ANTONIO, TX 78221
 FACILITY: DOS RIOS WATER RECYCLING CTR.
 LOCATION: 3495 VALLEY RD.
 SAN ANTONIO, TX 78221
 ATTN: PARVIZ CHAVOL SR DIR

TX0077801	102- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
 MAJOR (SUBR 13)
 TOTAL DISCHARGE - 001 & 101
 Internal Outfall
 No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	98.57	107.46		*****	*****	*****	*****	0	Continuous	
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	102.59	*****		*****	*****	*****	*****	0	Continuous	
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	125 ANNL AVG	*****	MGD	*****	*****	*****	*****		Continuous	TOTALZ

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Parviz Chavol Sr. Dir TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
			(210) 233-3239	05/11/2017
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 THE TOTAL DISCHARGE FROM OUTFALL 001 & OUTFALL 101 SHALL NEVER EXCEED 125 MGD AND SHALL BE REPORTED AS OUTFALL 102.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-033	02	17	04	12647
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR COMBINED MONITORING for 001/800/900
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	PERMITTED		VALUE	UNITS		
500507124 FLOW DLY AVG	REPORTED	PERMITTED	0	02		11	
					CONT	11	CONT
500507128 FLOW ANN AVG	REPORTED	PERMITTED	0	02		11	
					CONT	11	CONT
NUMBER OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01		NA	
					01 01	NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01		NA	
					01 01	NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01		NA	
					01 01	NA	NA
	REPORTED	PERMITTED					
	REPORTED	PERMITTED					
	REPORTED	PERMITTED					
	REPORTED	PERMITTED					
	REPORTED	PERMITTED					
	REPORTED	PERMITTED					
	REPORTED	PERMITTED					
	REPORTED	PERMITTED					

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.	NAME	SIGNATURE	DATE
	Timothy Howe Manager-Prod & Treat Ops		17 05 11
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
210 233 3239	Parviz Chavol Sr. Director		17 05 11
AREA CODE	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-033	02	17	04	12551
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE I
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
	REPORTED	PERMITTED		VALUE	UNITS			
000085342 TRANSFER DAYS/MON	REPORTED		30	DAY	0 01		01	
	PERMITTED					01 NA	01	NA
316164024 E-COLI DLY AVG	REPORTED		1.01	#/100 ML	0 11		03	
	PERMITTED		20.000			11 2/WEEK	03	GRABPKLOAD
316164030 E-COLI IND GRAB	REPORTED		1.10	#/100 ML	0 11		03	
	PERMITTED		75.000			11 2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED		2.57	MGD	0 02		11	
	PERMITTED					02 CONT	11	CONT
500507128 FLOW ANN AVG	REPORTED		1.93	MGD	0 02		11	
	PERMITTED					02 CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED		2.0	MG/L	0 08	1/Day	10	12-PRT-COM
	PERMITTED		5.000			11 2/WEEK	03	GRABPKLOAD
820796624 TURBDITY 30DAYAVG	REPORTED		1.27	NTU	0 08	1/Day	10	12-PRT-COM
	PERMITTED		3.000			11 2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED		WW0042725	NUMBER	0 01		NA	
	PERMITTED					01 01	NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		161022	DATE	0 01		NA	
	PERMITTED					01 01	NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		A	LETTER	0 01		NA	
	PERMITTED					01 01	NA	NA
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.

NAME
Timothy Howe
Manager-Prod & Treat Ops

SIGNATURE

DATE
17 05 11

TELEPHONE NUMBER
210 233 3239

PLANT OPERATOR
Parviz Chavol
Sr. Director

PLANT OPERATOR

PLANT OPERATOR
17 05 11

AREA CODE NUMBER EXECUTIVE OFFICER

EXECUTIVE OFFICER

EXECUTIVE OFFICER

YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

|||||

PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-033	02	17	04	12552
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE II
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	PERMITTED		VALUE	UNITS		
000085342 TRANSFER DAYS/MON	REPORTED	PERMITTED	0				
				DAY	01	NA	01 NA
316164024 FEC. COLI DLY AVG	REPORTED	PERMITTED					
				#/100 ML	14	1/WEEK	03 GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	PERMITTED					
				#/100 ML	14	1/WEEK	03 GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	PERMITTED					
				MGD	02	CONT	11 CONT
500507128 FLOW ANN AVG	REPORTED	PERMITTED					
				MGD	02	CONT	11 CONT
800821024 BOD CARB DLY AVG	REPORTED	PERMITTED					
				MG/L	14	1/WEEK	03 GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	WW0042725				NA
				NUMBER	01	01	NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	161022				NA
				DATE	01	01	NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	A				NA
				LETTER	01	01	NA NA
	REPORTED	PERMITTED					
	REPORTED	PERMITTED					

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.		NAME	SIGNATURE	DATE
		Timothy Howe Manager-Prod & Treat Ops		11/7 015/11
TELEPHONE NUMBER		PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
210	233	3239	Parviz Chavol Sr. Director	
AREA CODE	NUMBER		EXECUTIVE OFFICER	EXECUTIVE OFFICER
				11/7 015/11
				YEAR MO. DAY

OVERFLOW REPORT

PERIOD: APRIL 2017

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	478218	1726590	4/1/2017	Walnut Valley Dr 7003	5,600	Debris	Cleaned Main	1.87	1.55	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	1			Total Gallons:	5,600		Average Duration:	1.87	1.55	Average Response	

Tuesday, May 02, 2017

Note: Comments reflect status reported on the 5-Day report

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
NAME: SAN ANTONIO WATER SYSTEM
ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221
FACILITY: LEON CREEK WATER RECYCLING CENTER
LOCATION: 1104 MAURMAN ROAD
SAN ANTONIO, TX 78224
ATTN: PARVIZ CHAVOL, SR. DIRECTOR

TX0052639	001 - A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
MAJOR (SUBR 13)
DOMESTIC FACILITY - 001
External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****	6.60	*****	*****		0		
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	5 MO MIN	*****	*****	mg/L		Daily	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.50	*****	8.30		0		
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6 MINIMUM	*****	9 MAXIMUM	SU		Daily	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	332	*****		*****	1.15	2.10		0		
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	5755 DAILY AV	*****	lb/d	*****	15 DAILY AV	40 DAILY MX	mg/L		Daily	COMPOS
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	181	*****		*****	0.63	2.80		0		
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	767 DAILY AV	*****	lb/d	*****	2 DAILY AV	7 DAILY MX	mg/L		Daily	COMPOS
Chloride [as Cl]	SAMPLE MEASUREMENT	46,351	*****		*****	161	171		0		
00940 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	*****	lb/d	*****	Req. Mon. DAILY AV	Req. Mon. DAILY MX	mg/L		Daily	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	34.59	38.47		*****	*****	*****	*****	0		
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	*****	33,333		*****	*****	*****	*****	0		
50050 P 0 See Comments	PERMIT REQUIREMENT	*****	63889 2HR PEAK	gal/min	*****	*****	*****	*****		Continuous	TOTALZ

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
PARVIZ CHAVOL, SR. DIRECTOR			(210) 233-3239	05/11/2017
TYPED OR PRINTED			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THE COMBINED FLOW FOR OUTFALLS 001 AND 002 SHALL NOT EXCEED 46 MGD AND 2- HR PEAK OF 63889 GPM. POUNDS PER DAY LOADING SHALL ALSO BE THE COMBINED TOATL OF BOTH OUTFALLS.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: SAN ANTONIO WATER SYSTEM
ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221
FACILITY: LEON CREEK WATER RECYCLING CENTER
LOCATION: 1104 MAURMAN ROAD
SAN ANTONIO, TX 78224
ATTN: PARVIZ CHAVOL, SR. DIRECTOR

TX0052639	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
MAJOR (SUBR 13)
DOMESTIC FACILITY - 001
External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	36.60	*****		*****	*****	*****	*****	0		
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	46 ANNL AVG	*****	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0.09		0		
50060 A 0 Disinfection, Process Complete	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	.1 INST MAX	mg/L		Daily	GRAB
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	1.01	*****	*****		0		
50060 B 0 Prior to Disinfection	PERMIT REQUIREMENT	*****	*****	*****	1 MO MIN	*****	*****	mg/L		Daily	GRAB
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.06	3.00		0		
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	126 DAILY AV	399 DAILY MX	CFU/100 mL		Five per Week	GRAB
Solids, total dissolved	SAMPLE MEASUREMENT	227,753	*****		*****	792	990		0		
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	*****	lb/d	*****	Req. Mon. DAILY AV	Req. Mon. DAILY MX	mg/L		Daily	COMPOS
BOD, carbonaceous [5 day, 20 C]	SAMPLE MEASUREMENT	595	*****		*****	2.07	3.00		0		
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	2686 DAILY AV	*****	lb/d	*****	7 DAILY AV	17 DAILY MX	mg/L		Daily	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
PARVIZ CHAVOL, SR. DIRECTOR			(210) 233-3239	05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THE COMBINED FLOW FOR OUTFALLS 001 AND 002 SHALL NOT EXCEED 46 MGD AND 2- HR PEAK OF 63889 GPM. POUNDS PER DAY LOADING SHALL ALSO BE THE COMBINED TOATL OF BOTH OUTFALLS.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
NAME: SAN ANTONIO WATER SYSTEM
ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221
FACILITY: LEON CREEK WATER RECYCLING CENTER
LOCATION: 1104 MAURMAN ROAD
SAN ANTONIO, TX 78224
ATTN: PARVIZ CHAVOL, SR. DIRECTOR

TX0052639	002- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
MAJOR (SUBR 13)
DOMESTIC FACILITY - 002
External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****	6.90	*****	*****		0		
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	5 MO MIN	*****	*****	mg/L		Daily	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.70	*****	7.00		0		
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6 MINIMUM	*****	9 MAXIMUM	SU		Daily	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	1.46	*****		*****	1.00	1.00		0		
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	5755 DAILY AV	*****	lb/d	*****	15 DAILY AV	40 DAILY MX	mg/L		Daily	COMPOS
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	1.11	*****		*****	0.75	0.83		0		
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	767 DAILY AV	*****	lb/d	*****	2 DAILY AV	7 DAILY MX	mg/L		Daily	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.17	0.22		*****	*****	*****	*****	0		
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	*****	347		*****	*****	*****	*****	0		
50050 P 0 See Comments	PERMIT REQUIREMENT	*****	63889 2HR PEAK	gal/min	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.25	*****		*****	*****	*****	*****	0		
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	46 ANNL AVG	*****	MGD	*****	*****	*****	*****		Continuous	TOTALZ

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
PARVIZ CHAVOL, SR. DIRECTOR			(210) 233-3239	05/11/2017
TYPED OR PRINTED			AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THE COMBINED FLOW FOR OUTFALLS 001 AND 002 SHALL NOT EXCEED 46 MGD AND 2- HR PEAK OF 63889 GPM. POUNDS PER DAY LOADING SHALL ALSO BE THE COMBINED TOATL OF BOTH OUTFALLS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: SAN ANTONIO WATER SYSTEM
ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221
FACILITY: LEON CREEK WATER RECYCLING CENTER
LOCATION: 1104 MAURMAN ROAD
SAN ANTONIO, TX 78224
ATTN: PARVIZ CHAVOL, SR. DIRECTOR

TX0052639	002- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
MAJOR (SUBR 13)
DOMESTIC FACILITY - 002
External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Chlorine, total residual 50060 A 0 Disinfection, Process Complete	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0.07		0		
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	.1 INST MAX	mg/L		Daily	GRAB
Chlorine, total residual 50060 B 0 Prior to Disinfection	SAMPLE MEASUREMENT	*****	*****	*****	1.11	*****	*****		0		
	PERMIT REQUIREMENT	*****	*****	*****	1 MO MIN	*****	*****	mg/L		Daily	GRAB
E. coli 51040 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.00	1.00		0		
	PERMIT REQUIREMENT	*****	*****	*****	*****	126 DAILY AV	399 DAILY MX	CFU/100 mL		Five per Week	GRAB
BOD, carbonaceous [5 day, 20 C] 80082 1 0 Effluent Gross	SAMPLE MEASUREMENT	2.91	*****	*****	*****	2.00	2.00		0		
	PERMIT REQUIREMENT	2686 DAILY AV	*****	lb/d	*****	7 DAILY AV	17 DAILY MX	mg/L		Daily	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
PARVIZ CHAVOL, SR. DIRECTOR		(210) 233-3239	05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THE COMBINED FLOW FOR OUTFALLS 001 AND 002 SHALL NOT EXCEED 46 MGD AND 2- HR PEAK OF 63889 GPM. POUNDS PER DAY LOADING SHALL ALSO BE THE COMBINED TOATL OF BOTH OUTFALLS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
Different)
NAME: SAN ANTONIO WATER SYSTEM
ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221
FACILITY: LEON CREEK WATER RECYCLING CENTER
LOCATION: 1104 MAURMAN ROAD
SAN ANTONIO, TX 78224
ATTN: PARVIZ CHAVOL, SR. DIRECTOR

TX0052639	101- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
MAJOR (SUBR 13)
COMBINED OUTFALLS 001 & 002
External Outfall
No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT	332	*****		*****	*****	*****	*****	0		
00530 J 0 Intermediate Treatment, Process	PERMIT REQUIREMENT	5755 DAILY AV	*****	lb/d	*****	*****	*****	*****		Daily	COMPOS
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	181	*****		*****	*****	*****	*****	0		
00610 J 0 Intermediate Treatment, Process	PERMIT REQUIREMENT	767 DAILY AV	*****	lb/d	*****	*****	*****	*****		Daily	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	34.61	38.47		*****	*****	*****	*****	0		
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	*****	33,681		*****	*****	*****	*****	0		
50050 P 0 See Comments	PERMIT REQUIREMENT	*****	63889 2HR PEAK	gal/min	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	36.64	*****		*****	*****	*****	*****	0		
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	46 ANNL AVG	*****	MGD	*****	*****	*****	*****		Continuous	TOTALZ
BOD, carbonaceous [5 day, 20 C]	SAMPLE MEASUREMENT	595	*****		*****	*****	*****	*****	0		
80082 J 0 Intermediate Treatment, Process	PERMIT REQUIREMENT	2686 DAILY AV	*****	lb/d	*****	*****	*****	*****		Daily	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
PARVIZ CHAVOL, SR. DIRECTOR		(210) 233-3239		05/11/2017	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER


COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THE COMBINED FLOW FOR OUTFALLS 001 AND 002 SHALL NOT EXCEED 46 MGD AND 2- HR PEAK OF 63889 GPM. POUNDS PER DAY LOADING SHALL ALSO BE THE COMBINED TOATL OF BOTH OUTFALLS

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-003	02	17	04	12645
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR COMBINED MON 189 for 001/002/800/900

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE			
	REPORTED	PERMITTED			VALUE	UNITS		
500507124 FLOW DLY AVG	REPORTED		35.37	MGD	0	02	11	
	PERMITTED					02	CONT	11
500507128 FLOW ANN AVG	REPORTED		38.75	MGD	0	02	11	
	PERMITTED					02	CONT	11
NUMBER OF OPERATOR CERTIFICATE	REPORTED		WW0004506	NUMBER	0	01		NA
	PERMITTED					01	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		01/08/2017	DATE	0	01		NA
	PERMITTED					01	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		A	LETTER	0	01		NA
	PERMITTED					01	01	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							


COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.	NAME	SIGNATURE	DATE
	Daniel Rodriguez Manager Prod & Treat Ops		11/7/05/110
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
210 233 3239	Parviz Chavol Senior Director		11/7/05/111
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-003	02	17	04	12547
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE I 800

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
	REPORTED	PERMITTED		VALUE	UNITS			
000085342 TRANSFER DAYS/MON	REPORTED	PERMITTED	29	DAY	0 01		01	
316164024 E-COLI DLY AVG	REPORTED	PERMITTED	1.15	#/100 ML	0 11		03	
316164030 E-COLI IND GRAB	REPORTED	PERMITTED	3.00	#/100 ML	0 11		03	
500507124 FLOW DLY AVG	REPORTED	PERMITTED	0.80	MGD	0 02		11	
500507128 FLOW ANN AVG	REPORTED	PERMITTED	2.17	MGD	0 02		11	
800821024 BOD CARB DLY AVG	REPORTED	PERMITTED	2.03	MG/L	0 08	1/Day	10	12-prt-com
820786624 TURBIDITY 30DAY AV	REPORTED	PERMITTED	0.90	NTU	0 08	1/Day	10	12-prt-com
NUMBER OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	WW0004506	NUMBER	0 01		NA	
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	01/08/2017	DATE	0 01		NA	
CLASS OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	A	LETTER	0 01		NA	
	REPORTED	PERMITTED						

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.

	NAME	SIGNATURE	DATE
	Daniel Rodriguez Manager Prod & Treat Ops		1/7 015/10
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
210 233 3239	Parviz Chavol Senior Director		1/7 015/11
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

|||||

PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-003	02	17	04	12548
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE II 900

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	PERMITTED		VALUE	UNITS		
000085342 TRANSFER DAYS/MON	REPORTED	PERMITTED	0	01		01	
					01	NA	01 NA
316164024 FEC. COLI DLY AVG	REPORTED	PERMITTED					
					14	1/WEEK	03 GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	PERMITTED					
					14	1/WEEK	03 GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	PERMITTED					
					02	CONT	11 CONT
500507128 FLOW ANN AVG	REPORTED	PERMITTED					
					02	CONT	11 CONT
800821024 BOD CARB DLY AVG	REPORTED	PERMITTED					
					14	1/WEEK	03 GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01			NA
					01	01	NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01			NA
					01	01	NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01			NA
					01	01	NA NA
	REPORTED	PERMITTED					
	REPORTED	PERMITTED					

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.	NAME	SIGNATURE	DATE
	Daniel Rodriguez Manager Prod & Treat Ops		11/05/10
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
210 233 3239	Parviz Chavol Senior Director		11 05 11
AREA CODE	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

OVERFLOW REPORT

PERIOD:

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Average Duration:			Average Response		

Tuesday, May 02, 2017

Note: Comments reflect status reported on the 5-Day report

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
Different)
NAME: MEDIO CREEK WATER RECYCLING CENTER
ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221
FACILITY: MEDIO CREEK WATER RECYC. CTR.
LOCATION: 2231 HUNT LANE
SAN ANTONIO, TX 78227
ATTN: PARVIZ CHAVOL SR DIR

TX0055689	001- B
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
MAJOR (SUBR 13)
DOMESTIC FACILITY - 001
External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****	6.23	*****	*****		0		
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6 MO MIN	*****	*****	mg/L		Daily	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.09	*****	8.19		0		
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6 MINIMUM	*****	9 MAXIMUM	SU		Daily	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	48	*****		*****	1.25	4.30		0		
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	2002 DAILY AV	*****	lb/d	*****	15 DAILY AV	30 DAILY MX	mg/L		Daily	COMPOS
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	41	*****		*****	1.06	3.08		0		
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	267 DAILY AV	*****	lb/d	*****	2 DAILY AV	7 DAILY MX	mg/L		Daily	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	4.54	6.43		*****	*****	*****	*****	0		
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	*****	7,264		*****	*****	*****	*****	0		
50050 P 0 See Comments	PERMIT REQUIREMENT	*****	27778 2HR PEAK	gal/min	*****	*****	*****	*****		Continuous	TOTALZ
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	5.55	*****		*****	*****	*****	*****	0		
50050 Y 0 Effluent Gross (Supplementary)	PERMIT REQUIREMENT	16 ANNL AVG	*****	MGD	*****	*****	*****	*****		Continuous	TOTALZ

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
PARVIZ CHAVOL, SR. DIR.		(210) 233-3239	05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: MEDIO CREEK WATER RECYCLING CENTER
ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221
FACILITY: MEDIO CREEK WATER RECYC. CTR.
LOCATION: 2231 HUNT LANE
SAN ANTONIO, TX 78227
ATTN: PARVIZ CHAVOL SR DIR

TX0055689	001-B
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
MAJOR
(SUBR 13)
DOMESTIC FACILITY - 001
External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.00	1.00		0		
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	126 DAILY AV	399 DAILY MX	CFU/100 mL		Daily	GRAB
BOD, carbonaceous [5 day, 20 C]	SAMPLE MEASUREMENT	88	*****		*****	2.37	4.00		0		
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	934 DAILY AV	*****	lb/d	*****	7 DAILY AV	20 DAILY MX	mg/L		Daily	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
PARVIZ CHAVOL, SR. DIR.			(210) 233-3239	05/11/2017
TYPED OR PRINTED			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3225 VALLEY RD
SAN ANTONIO TX 78221-5201



40B	WQ0010137-040	01	17	04	12654
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR COMBINED MON 189 for 001/800/900 MEDIO CREEK

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
	REPORTED	PERMITTED		VALUE	UNITS			
500507124 FLOW	REPORTED		6.40	MGD	0	02	11	
DLY AVG	PERMITTED					02	CONT	11 CONT
500507128 FLOW	REPORTED		7.50	MGD	0	02	11	
ANN AVG	PERMITTED					02	CONT	11 CONT
NUMBER OF OPERATOR CERTIFICATE	REPORTED		WW0004506	NUMBER	0	01		NA
	PERMITTED					01	01	NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		01/08/2020	DATE	0	01		NA
	PERMITTED					01	01	NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		A	LETTER	0	01		NA
	PERMITTED					01	01	NA NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							


COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.

	NAME	SIGNATURE	DATE
	Daniel Rodriguez Manager-Prod & Treat Ops		11/7/05/116
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
210 233 3239	Parviz Chavol Senior Director		11/05/111
AREA CODE	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3225 VALLEY RD
SAN ANTONIO TX 78221-5201



40B	WQ0010137-040	01	17	04	12553
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE I 800

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
		VALUE		UNITS				
000085342 TRANSFER DAYS/MON	REPORTED	30	DAY	0	01		01	
	PERMITTED				01	NA	01	NA
316164024 FEC. COLI DLY AVG	REPORTED	1.45	#/100 ML	0	11		03	
	PERMITTED	20.000			11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	20.00	#/100 ML	0	11		03	
	PERMITTED	75.000			11	2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	1.86	MGD	0	02		11	
	PERMITTED				02	CONT	11	CONT
500507128 FLOW ANN AVG	REPORTED	1.98	MGD	0	02		11	
	PERMITTED				02	CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED	2.37	MG/L	0	08	1/Day	10	12-prt-com
	PERMITTED	5.000			11	2/WEEK	03	GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED	0.86	NTU	0	08	1/Day	10	12-prt-com
	PERMITTED	3.000			11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0004506	NUMBER	0	01		NA	
	PERMITTED				01	01	NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	01/08/2020	DATE	0	01		NA	
	PERMITTED				01	01	NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01		NA	
	PERMITTED				01	01	NA	NA
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.

	NAME	SIGNATURE	DATE
	Daniel Rodriguez Manager-Prod & Treat Ops		17 05 10
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
2 10 233 3239	Parviz Chavol Senior Director		17 05 11
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3225 VALLEY RD
SAN ANTONIO TX 78221-5201



40B	WQ0010137-040	02	17	04	12554
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE II 900

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
		VALUE		UNITS			
000085342 TRANSFER DAYS/MON	REPORTED	0	DAY	0	01		01
	PERMITTED						
316164024 FEC. COLI DLY AVG	REPORTED		#/100 ML				
	PERMITTED	200.000					
316164030 FEC. COLI IND GRAB	REPORTED		#/100 ML				
	PERMITTED	800.000					
500507124 FLOW DLY AVG	REPORTED		MGD				
	PERMITTED						
500507128 FLOW ANN AVG	REPORTED		MGD				
	PERMITTED						
800821024 BOD CARB DLY AVG	REPORTED		MG/L				
	PERMITTED	20.000					
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0004506	NUMBER	0	01		NA
	PERMITTED						
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	01/08/2020	DATE	0	01		NA
	PERMITTED						
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01		NA
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.

	NAME	SIGNATURE	DATE
	Daniel Rodriguez Manager-Prod & Treat Ops		11/7/05/10
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
210 233 3239	Parviz Chavol Senior Director		11/7/05/11
AREA CODE	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY



Ms. Rosie Garza
 Texas Commission on Environmental Quality
 Water Quality Management Information Systems (MC 224)
 12100 Park 35 Circle, Bldg. F.
 Austin, Texas 78711-3087

April, 7, 2017

Re: Non-Compliance Notification
 TPDES Permit No. 10137-004, Mitchell Lake
 EPA ID No. TX0065641

Dear Ms. Garza,

The following are the Mitchell Lake Dam effluent excursions for the daily pH for the month of April 2017.

pH	pH	TSS Monthly Avg. 104.61 mg/l
Apr. 1, 2017 - 9.40 SU	Apr. 14, 2017 - 9.47 SU	
Apr. 2, 2017 - 9.50 SU	Apr. 15, 2017 - 9.40 SU	
Apr. 3, 2017 - 9.90 SU	Apr. 16, 2017 - 9.50 SU	
Apr. 4, 2017 - 9.80 SU	Apr. 17, 2017 - 9.30 SU	
Apr. 5, 2017 - 9.30 SU	Apr. 18, 2017 - 9.44 SU	
Apr. 6, 2017 - 9.80 SU	Apr. 19, 2017 - 9.60 SU	
Apr. 7, 2017 - 9.60 SU	Apr. 20, 2017 - 9.70 SU	
Apr. 8, 2017 - 9.60 SU	Apr. 22, 2017 - 9.39 SU	
Apr. 9, 2017 - 9.79 SU	Apr. 23, 2017 - 9.92 SU	
Apr. 10, 2017 - 9.29 SU	Apr. 24, 2017 - 9.93 SU	
Apr. 11, 2017 - 9.70 SU	Apr. 25, 2017 - 9.90 SU	
Apr. 12, 2017 - 9.80 SU	Apr. 26, 2017 - 10.0 SU	
Apr. 13, 2017 - 9.45 SU	Apr. 27, 2017 - 9.67 SU	

If additional discussion is needed regarding this event, please contact Daniel Rodriguez at 210-233-3922.

Daniel Rodriguez
 Manager, Leon Creek WRC
 1104 Mauermann
 San Antonio, TX 78224

cc: Jeff Haby
 Parviz Chavol
 Floramie Welch

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: SAN ANTONIO WATER SYSTEM
ADDRESS: 3495 VALLEY RD
SAN ANTONIO, TX 78221
FACILITY: MITCHELL LAKE WWTF
LOCATION: 10762 PLEASANTON RD
SAN ANTONIO, TX 78212
ATTN: PARVIZ CHAVOL, SR. DIRECTOR

TX0065641	001- A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2017	04/30/2017

DMR Mailing ZIP CODE: 78221
MINOR
(SUBR 13)
DOMESTIC FACILITY - 001
External Outfall

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****	9.60	*****	*****		0		
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	4 MO MIN	*****	*****	mg/L		Daily	GRAB
BOD, 5- day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****	22.00	35.00		0		
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	30 DAILY AV	100 SINGGRAB	mg/L		Daily	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	8.90	*****	10.00		26		
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6 MINIMUM	*****	9 MAXIMUM	SU		Monthly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	104.61	*****		1		
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	90 DAILY AV	*****	mg/L		Daily	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	4.36	18.03		*****	*****	*****	*****	0		
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. DAILY AV	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Daily	INSTAN
E. coli	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.07	3.00		0		
51040 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	126 DAILY AV	399 SINGGRAB	CFU/100 mL		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
PARVIZ CHAVOL, SR. DIR			(210) 233-3239	05/11/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
MONITORING SHALL OCCUR WHEN DISCHARGING.
SAMPLES FOR BACTERIA MONITORING SHALL BE TAKEN AT THE INFLOW PIPE FROM THE LEON CREEK WRC.