



July 17, 2018

U.S. Department of Justice
Environmental Enforcement Section
Environment and Natural Resources Division
P.O. Box 7611
Washington, D.C. 20044-7611

Via U.S. Certified Mail
RRR# 7017 1000 0000 0971 6922

Re: DOJ Case No. [90-5-1-1-09215]

Consent Decree

Date of Lodging: July 23, 2013

Date of Entry: October 15, 2013

CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 a. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of the monthly compliance report required by its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. A copy of the monthly compliance report for June 2018 is attached and is provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby".

Jeffrey J. Haby, P.E.

Vice President – Production & Treatment

Enc. As stated



July 17, 2018

U.S. Environmental Protection Agency, Region VI
Chief, Water Enforcement Branch (6EN-W)
Compliance Assurance and Enforcement Division
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR #7017 1000 0000 0971 6939

U.S. Environmental Protection Agency, Region VI
Attn: Ms. Judy Edelbrock (6EN-W)
Environmental Protection Specialist
Enforcement Branch
1445 Ross Avenue
Dallas, TX 75202-2733

Via U.S. Certified Mail
RRR #7017 1000 0000 0971 6939

Re: DOJ Case No. [90-5-1-1-09215]

Consent Decree

Date of Lodging: July 23, 2013

Date of Entry: October 15, 2013

CA No. 5:13-cv-00666-DAE, United States of America and State of Texas v. San Antonio Water System, in the United States District Court for the Western District of Texas, San Antonio Division

Dear Sir/Madam:

Section 12 a. of the above-referenced Consent Decree requires that within 90 days after Lodging the San Antonio Water System shall provide a copy of the monthly compliance report required by its TPDES permits to the United States Environmental Protection Agency at the same time the report is submitted to the Texas Commission on Environmental Quality. A copy of the monthly compliance report for June 2018 is attached and is provided in compliance with Consent Decree requirements.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeffrey J. Haby".

Jeffrey J. Haby, P.E.

Vice President – Production & Treatment

Enc. As stated

OVERFLOW REPORT

PERIOD: JUNE 2018

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	527906	2337727	6/25/2018	Rio Grande St N	1000	Debris	Cleaned Main	0.87	0.37	Street	Area Cleaned and Disinfected, Flushed Area with H2O Returned To System
	527388	2328962	6/19/2018	De Zavala Rd	5150	Debris	Cleaned Main	1.50	0.70	Drainage Culvert - Over The Edwards Recharge Zone	Area Cleaned and Disinfected, Flushed Area with H2O
	526986	2324385	6/15/2018	Muncey	1112	Debris	Cleaned Main	0.67	0.50	Street	Area Cleaned and Disinfected, Flushed Area with H2O
	1558364	2323973	6/15/2018	Dolorosa	823	Structural	Repaired Main	1.67	0.30	Street	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Created To Repair Sewer Main
	526354	2312172	6/8/2018	Walton Ave	300	Grease	Cleaned Main	0.98	0.17	Ground	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:					5	Total Gallons:	8,351	Average Duration:	1.14	Average Response	0.41

Thursday, July 05, 2018

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: JUNE 2018

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
1563248	528408	2346194	6/29/2018	Wild Springs Dr	20818	215 Contractor	Cleaned Main	0.72	0.63	Drainage Culvert - Over The Edwards Aquifer Recharge Zone	Area Cleaned and Disinfected, Flushed Area with H2O - Work Order Created To Repair Sewer Main
527800	2335349		6/23/2018	Sonterra Blvd	901	75 Debris	Cleaned Main	1.25	0.83	Street - Over The Edwards Recharge Zone	Area Cleaned and Disinfected, Flushed Area with H2O
526578	2317603		6/12/2018	Sunset Rd E	234	84 Contractor	Cleaned Main	1.40	0.77	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
1555683	526360	2313383	6/8/2018	Wild Springs Dr	20814	200 Contractor	Repaired Main	2.90	0.00	Ground - Over The Edwards Aquifer Recharge Zone	Area Cleaned and Disinfected, Work Order Created To Repair Main
Total Events: 4					Total Gallons: 574	Average Duration: 1.57		Average Response			

Thursday, July 05, 2018

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD:

WATERSHED: SUBSCRIBER

TCEQ PERMIT # Subscriber

EPA PERMIT # Subscriber

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Gallons:								Average Duration:			
Total Events:								Average Response			

Thursday, July 05, 2018

Note: Comments reflect status reported on the 5-Day report

Edit DMR

Collapse Header

Permit

Permit ID:

Permittee:

Facility:

Permitted Feature:

Report Dates & Status

Monitoring Period:

Status:

Principal Executive Officer

First Name:

Title:

No Data Indicator (NODI)

Form NODI:

TX0077801
 SAN ANTONIO WATER SYSTEM
 DOS RIOS WATER RECYCLING CTR.
 001 - External Outfall
 From 06/01/18 to 06/30/18
 NetDMR Validated
 Parviz
 Sr. Director

Major:

Permittee Address:

Facility Location:

Discharge:

DMR Due Date:

Last Name:

Telephone:

2800 US HIGHWAY 281 NORTH
 SAN ANTONIO, TX 78212
 3495 VALLEY RD.
 SAN ANTONIO, TX 78221
 A - DOMESTIC FACILITY - 001

07/20/18

Chavol
 210-233-3239

Parameter Code	Name	NODI	Quantity or Loading		Quality or Concentration		# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2	Value 1	Value 2			
00300	Oxygen, dissolved [DO]	Smpl.	[v] 7.4	[v] 4	[v] 7.41	[v] 4	[v] 01/01	[v] GR	[v] GR
1 - Effluent Gross		Req.	>= 6 Monthly Minimum	[v]					GRAB
Season: 0		NODI	[v]	[v]					
00400	pH	Smpl.	[v] 7	[v] 7	[v] 7.41	[v] 7	[v] 01/01	[v] GR	[v] GR
1 - Effluent Gross		Req.	>= 6 Minimum	[v]					GRAB
Season: 0		NODI	[v]	[v]					
00530	Solids, total suspended	Smpl.	[v] 1.46	[v] 0.00	[v] 1.46	[v] 0.00	[v] 01/01	[v] CP	[v] CP
1 - Effluent Gross		Req.	<= 12510 Daily Average	[v]					COMPOS
Season: 0		NODI	[v]	[v]					
00610	Nitrogen ammonia total [as N]	Smpl.	[v] 17.4	[v] 25	[v] 17.4	[v] 25	[v] 01/01	[v] CP	[v] CP
1 - Effluent Gross		Req.	<= 2085 Daily Average	[v]					COMPOS
Season: 0		NODI	[v]	[v]					

Code	Parameter Name	NODI	Quantity or Loading		Units	Value 1	Quality or Concentration		Units	# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2			Value 2	Value 3				
50050	Flow, in conduit or thru treatment plant	Smpl.	= 89.54	= 89.4	MGD					0	99/99	TM
1 - Effluent Gross												
Season: 0		Req.	Req Mon Daily Average	Req Mon Daily Maximum	Million Gallons per Day						Continuous	TOTAL
NODI:												
50050	Flow, in conduit or thru treatment plant	Smpl.	= 75370		gal/min					0	01/30	TM
P - See Comments												
Season: 0		Req.	<= 173611.2 Hour Peak		Gallons per Minute						Monthly	TOTAL
NODI:												
50050	Flow, in conduit or thru treatment plant	Smpl.	= 3.56		MGD					0	99/99	TM
Y - Effluent Gross (Supplementary)												
Season: 0		Req.	<= 125 Annual Average		Million Gallons per Day						Continuous	TOTAL
NODI:												
50060	Chlorine, total residual	Smpl.								0	01/01	GR
A - Disinfection, Process Complete												
Season: 0		Req.								0	01/01	GR
NODI:												
50060	Chlorine, total residual	Smpl.	= 1.06							0	01/01	GR
B - Prior to Disinfection												
Season: 0		Req.	>= 1 Monthly Minimum								Daily	GRAB
NODI:												
51040	E. coli	Smpl.								0	01/01	GR
1 - Effluent Gross												
Season: 0		Req.	<= 126 Daily Average							0	07/WK	GR
NODI:												
51040	E. coli	Smpl.								0	07/WK	GR
1 - Effluent Gross												
Season: 0		Req.	<= 399 Daily Maximum								Five Per Week	GRAB
NODI:												

Edit DMR

Collapse Header

Permit

Permit ID: TX0077801
 Permittee: SAN ANTONIO WATER SYSTEM

Facility

DOS RIOS WATER RECYCLING CTR.

Permitted Feature:

002 - External Outfall

Report Dates & Status

From 06/01/18 to 06/30/18

Monitoring Period:

NetDMR Validated

Status:

NetDMR Validated

Principal Executive Officer

First Name:

Parviz

Title:

Sr. Director

No Data Indicator (NODI)

Form NODI:

Parameter

Code

Name

NODI

Smpl.

Req.

NODI

Smpl.

Req.

NODI

Smpl.

Req.

NODI

Smpl.

Req.

NODI

Smpl.

Req.

NODI

Smpl.

Req.

NODI

Smpl.

Req.

NODI

Major:

Permittee Address:

2800 US HIGHWAY 281 NORTH
 SAN ANTONIO, TX 78212
 3495 VALLEY RD.

Facility Location:

SAN ANTONIO, TX 78221
 A - DOMESTIC FACILITY - 002

Discharge:

DMR Due Date:

07/20/18

Last Name:

Chavol

Telephone:

210-233-3239

Code	Name	NODI	Value 1	Quantity or Loading	Value 2	Units	Value 1	Quality or Concentration	Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
00300	Oxygen, dissolved [DO]						= > 4				mg/L	0	01/01	GR
1 - Effluent Gross							> = 4 Monthly Minimum				Milligrams per Liter	0	Daily	GRAB
Season: 0														
NODI:														
00400	pH						= > 7				SU	0	01/01	GR
1 - Effluent Gross							> = 6.5 Minimum				Standard Units	0	Daily	GRAB
Season: 0														
NODI:														
00530	Solids, total suspended						= < 100.86				mg/L	0	01/01	CP
1 - Effluent Gross							< = 1251 Daily Average				Milligrams per Liter	0	Daily	COMPOS
Season: 0														
NODI:														
00610	Nitrogen ammonia total [as N]						= < 0.25				mg/L	0	01/01	CP
1 - Effluent Gross							< = 2 Daily Average				Milligrams per Liter	0	Daily	COMPOS
Season: 0														
NODI:														

Parameter Code	Parameter Name	NODI	Value 1	Quantity or Loading	Value 2	Units	Value 1	Quality or Concentration	Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
50050	Flow, in conduit or thru treatment plant	Smpl.	= 0.88		= 4.89	MGD						0	99/99	TM
1 - Effluent Gross														
Season: 0		Req.	Req Mon Daily Average		Req Mon Daily Maximum	Million Gallons per Day							Continuous	TOTAL
NODI:														
50050	Flow, in conduit or thru treatment plant	Smpl.	= 0.74			MGD						0	01/20	TM
Y - Effluent Gross (Supplementary)														
Season: 0		Req.	<= 10 Annual Average			Million Gallons per Day							Monthly	TOTAL
NODI:														
50060	Chlorine, total residual	Smpl.						= 0.06			mg/L	0	01/01	GR
A - Disinfection, Process Complete														
Season: 0		Req.						< .1 Instantaneous Maximum			Milligrams per Liter		Daily	GRAB
NODI:														
50060	Chlorine, total residual	Smpl.									mg/L	0	01/01	GR
B - Prior to Disinfection														
Season: 0		Req.									Milligrams per Liter		Daily	GRAB
NODI:														
51040	E. coli	Smpl.						= 1.23			CFU/100ml	0	07/00	GR
1 - Effluent Gross														
Season: 0		Req.						<= 63 Daily Average			Colony Forming Units per 100ml		Three Per Week	GRAB
NODI:														
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.	= 70.03			lb/d		= 0.17			mg/L	0	01/01	CP
1 - Effluent Gross														
Season: 0		Req.	<= 834 Daily Average			Pounds per Day		<= 10 Daily Average			Milligrams per Liter		Daily	COMPOS
NODI:														

Edit DMR

Collapse Header

Permit

Permit ID: TX0077801
 Permittee: SAN ANTONIO WATER SYSTEM

Facility: DOS RIOS WATER RECYCLING CTR.

Permitted Feature: 003 - External Outfall

Report Dates & Status: From 06/01/18 to 06/30/18
 Monitoring Period: NetDMR Validated

Principal Executive Officer

First Name: Parviz
 Title: Sr. Director

No Data Indicator (NODI) Form NODI:

003

Major: 2800 US HIGHWAY 281 NORTH
 Permittee Address: SAN ANTONIO, TX 78212
 3495 VALLEY RD.
 Facility Location: SAN ANTONIO, TX 78221
 A - DOMESTIC FACILITY - 003
 Discharge: 07/20/18
 DMR Due Date: Chaval
 Last Name: 210-233-3239
 Telephone:

Parameter Code	Name	NODI	Quantity or Loading	Value 1	Value 2	Units	Value 1	Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Simpl. Type
00300	Oxygen, dissolved [DO]	Smpl.								mg/L			
1 - Effluent Gross													
Season:	0	Req.					>= 4 Monthly Minimum			Milligrams per Liter		Daily	GRAB
NODI:		NODI											
00400	pH	Smpl.								SU			
1 - Effluent Gross													
Season:	0	Req.					>= 6 Minimum			Standard Units		Daily	GRAB
NODI:		NODI											
00530	Solids, total suspended	Smpl.								mg/L			
1 - Effluent Gross													
Season:	0	Req.	<= 1251 Daily Average							Milligrams per Liter		Daily	COMPOS
NODI:		NODI											
00610	Nitrogen, ammonia total [as N]	Smpl.								mg/L			
1 - Effluent Gross													
Season:	0	Req.	<= 167 Daily Average							Milligrams per Liter		Daily	COMPOS
NODI:		NODI											

Code	Parameter Name	NODI	Value 1	Quantity or Loading	Value 2	Units	Value 1	Quality or Concentration	Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
50050	Flow, in conduit or thru treatment plant	Smpl.				MGD								
1 - Effluent Gross														
Season: 0		Req.	Req Mon Daily Average	Req Mon Daily Maximum		Million Gallons per Day							Continuous	TOTAL
NODI: [v]		NODI	[C]	[C]		MGD								[v]
50050	Flow, in conduit or thru treatment plant	Smpl.				MGD								
Y - Effluent Gross (Supplementary)														
Season: 0		Req.	<= 10 Annual Average			Million Gallons per Day							Monthly	TOTAL
NODI: [v]		NODI	[C]	[C]		Million Gallons per Day								[v]
50060	Chlorine, total residual	Smpl.									mg/L			
A - Disinfection, Process Complete														
Season: 0		Req.									mg/L		Daily	GRAB
NODI: [v]		NODI						< .1 Instantaneous Maximum			Milligrams per Liter		Daily	GRAB
50060	Chlorine, total residual	Smpl.									mg/L			
B - Prior to Disinfection														
Season: 0		Req.									Milligrams per Liter		Daily	GRAB
NODI: [v]		NODI									Milligrams per Liter		Daily	GRAB
51040	E. coli	Smpl.									CFU/100mL			
1 - Effluent Gross														
Season: 0		Req.									CFU/100mL		Three Per Week	GRAB
NODI: [v]		NODI									Colony Forming Units per 100ml		Three Per Week	GRAB
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.									mg/L			
1 - Effluent Gross														
Season: 0		Req.	<= 834 Daily Average			Pounds per Day					Milligrams per Liter		Daily	COMPOS
NODI: [v]		NODI	[C]	[C]		Pounds per Day					Milligrams per Liter		Daily	COMPOS

Edit DMR

Collapse Header

Permit

Permit ID: TX0077801

Permittee: SAN ANTONIO WATER SYSTEM

Facility: DOS RIOS WATER RECYCLING CTR.

Permitted Feature: 004 - External Outfall

Report Dates & Status: From 06/01/18 to 06/30/18

Monitoring Period: NetDMR Validated

Status: NetDMR Validated

Principal Executive Officer

First Name: Parviz

Title: Sr. Director

No Data Indicator (NODI)

Form NODI:

Major: 2800 US HIGHWAY 281 NORTH
 Permittee Address: SAN ANTONIO, TX 78212
 3495 VALLEY RD.
 Facility Location: SAN ANTONIO, TX 78221
 Discharge: A - DOMESTIC FACILITY - 004
 DMR Due Date: 07/20/18
 Last Name: Chaval
 Telephone: 210-233-3239

004

Parameter Code	NODI	Name	Quantity or Loading	Value 1	Value 2	Units	Value 1	Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
00300		Oxygen, dissolved [DO]					= 5.6			mg/L	0	01/01	GR
1 - Effluent Gross							> = 5 Monthly Minimum			Milligrams per Liter	0	Daily	GRAB
Season: 0													
NODI: [v]													
00400		pH					= 7.1			SU	0	01/01	GR
1 - Effluent Gross							> = 6.5 Minimum			Standard Units	0	Daily	GRAB
Season: 0													
NODI: [v]													
00530		Solids, total suspended					= 7.54			mg/L	0	01/01	CP
1 - Effluent Gross							< = 375 Daily Average			Milligrams per Liter	0	Daily	COMPOS
Season: 0													
NODI: [v]													
00610		Nitrogen, ammonia total [as N]					= 7.15			mg/L	0	01/01	CP
1 - Effluent Gross							< = 2 Daily Average			Milligrams per Liter	0	Daily	COMPOS
Season: 0													
NODI: [v]													

Code	Parameter Name	NODI	Quantity or Loading		Quality or Concentration		# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2	Value 1	Value 2			
50050	Flow, in conduit or thru treatment plant	Smpl.	= 0.03	= 0.03			0	99999	TM
1 - Effluent Gross									
Season: 0		Req.	Req Mon Daily Average	Req Mon Daily Maximum				Continuous	TOTAL
NODI: 0		NODI							
50050	Flow, in conduit or thru treatment plant	Smpl.	= 0.58				0	01/30	TM
Y - Effluent Gross (Supplementary)									
Season: 0		Req.	<= 3 Annual Average					Monthly	TOTAL
NODI: 0		NODI							
50060	Chlorine, total residual	Smpl.					0	01/01	GR
A - Disinfection, Process Complete									
Season: 0		Req.						Daily	GRAB
NODI: 0		NODI							
50060	Chlorine, total residual	Smpl.	= 0.06				0	01/01	GR
B - Prior to Disinfection									
Season: 0		Req.	>= 1 Monthly Minimum					Daily	GRAB
NODI: 0		NODI							
51040	E. coli	Smpl.					0	01/01	GR
1 - Effluent Gross									
Season: 0		Req.						Weekly	GRAB
NODI: 0		NODI							
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.	= 10.69				0	01/01	CP
1 - Effluent Gross									
Season: 0		Req.	<= 250 Daily Average					Daily	COMPOS
NODI: 0		NODI							

Edit DMR

Collapse Header

Permit

Permit ID: TX0077801
 Permittee: SAN ANTONIO WATER SYSTEM

Facility: DOS RIOS WATER RECYCLING CTR.

Permitted Feature:

005 - External Outfall

Report Dates & Status

Monitoring Period: From 06/01/18 to 06/30/18

Status:

NetDMR Validated

Principal Executive Officer

First Name: Parviz
 Title: Sr. Director

No Data Indicator (NODI)

Form NODI:

Major: 2800 US HIGHWAY 281 NORTH
 Permittee Address: SAN ANTONIO, TX 78212
 3495 VALLEY RD.
 Facility Location: SAN ANTONIO, TX 78221
 Discharge: A - DOMESTIC FACILITY - 005
 DMR Due Date: 07/20/18
 Last Name: Chavol
 Telephone: 210-233-3239

005

Parameter Code	Name	NODI	Value 1	Value 2	Quantity or Loading	Units	Value 1	Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
00300	Oxygen, dissolved [DO]	Smpl.					= <input type="text" value="β 7"/>			mg/L	β	0101	GR
	1 - Effluent Gross						>= 4 Monthly Minimum			Milligrams per Liter		Daily	GRAB
	Season: 0	Req.					<input type="text" value="β"/>						
	NODI: <input type="text"/>	NODI											
00400	pH	Smpl.					= <input type="text" value="β"/>			SU	β	0101	GR
	1 - Effluent Gross						<= 9 Maximum			Standard Units		Daily	GRAB
	Season: 0	Req.					<input type="text" value="β"/>						
	NODI: <input type="text"/>	NODI											
00530	Solids, total suspended	Smpl.					= <input type="text" value="β 08"/>			mg/L	β	0101	CP
	1 - Effluent Gross						<= 15 Daily Average			Milligrams per Liter		Daily	COMPOS
	Season: 0	Req.					<input type="text" value="β"/>						
	NODI: <input type="text"/>	NODI											
00610	Nitrogen, ammonia total (as N)	Smpl.					= <input type="text" value="β 25"/>			mg/L	β	0101	CP
	1 - Effluent Gross						<= 7 Daily Maximum			Milligrams per Liter		Daily	COMPOS
	Season: 0	Req.					<input type="text" value="β"/>						
	NODI: <input type="text"/>	NODI											

Parameter Code	Parameter Name	NODI	Quantity or Loading		Quality or Concentration		# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2	Value 1	Value 2			
50050	Flow, in conduit or thru treatment plant	Smpl.	= 0.88	= 1.85			0	9999	TM
1 - Effluent Gross									
Season: 0		Req.	Req Mon Daily Average	Req Mon Daily Maximum				Continuous	TOTAL
NODI:		NODI							
50050	Flow, in conduit or thru treatment plant	Smpl.	= 0.62				0	01750	TM
Y - Effluent Gross (Supplementary)									
Season: 0		Req.	<= 2.6 Annual Average					Monthly	TOTAL
NODI:		NODI							
50060	Chlorine, total residual	Smpl.					0	01101	GR
A - Disinfection, Process Complete									
Season: 0		Req.						Daily	GRAB
NODI:		NODI							
50060	Chlorine, total residual	Smpl.	= 1.08				0	01101	GR
B - Prior to Disinfection									
Season: 0		Req.	>= 1 Monthly Minimum					Daily	GRAB
NODI:		NODI							
51040	E. coli	Smpl.					0	017MM	GR
1 - Effluent Gross									
Season: 0		Req.						Weekly	GRAB
NODI:		NODI							
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.	= 15.75				0	01101	CP
1 - Effluent Gross									
Season: 0		Req.	<= 217 Daily Average					Daily	COMPOS
NODI:		NODI							

Edit DMR

Collapse Header

Permit

Permit ID: TX0077801

Permittee: SAN ANTONIO WATER SYSTEM

Facility: DOS RIOS WATER RECYCLING CTR.

Permitted Feature: 006 - External Outfall

Report Dates & Status: From 06/01/18 to 06/30/18

Monitoring Period: NetDMR Validated

Status: NetDMR Validated

Principal Executive Officer

First Name: Parviz

Title: Sr. Director

No Data Indicator (NODI)

Form NODI:

Major:

Permittee Address: 2800 US HIGHWAY 281 NORTH
SAN ANTONIO, TX 78212
3495 VALLEY RD.

Facility Location: SAN ANTONIO, TX 78221
A - DOMESTIC FACILITY - 006

Discharge: 07/20/18

DMR Due Date: 07/20/18

Last Name: Chavol

Telephone: 210-233-3239

004

Code	Parameter Name	NODI	Quantity or Loading		Quality or Concentration			# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2	Value 1	Value 2	Value 3			
00300	Oxygen, dissolved [DO]									
	1 - Effluent Gross	Smpl.								
	Season: 0	Req.								
	NODI: <input type="checkbox"/>	NODI								
00400	pH									
	1 - Effluent Gross	Smpl.								
	Season: 0	Req.								
	NODI: <input type="checkbox"/>	NODI								
00530	Solids, total suspended									
	1 - Effluent Gross	Smpl.								
	Season: 0	Req.								
	NODI: <input type="checkbox"/>	NODI								
00610	Nitrogen, ammonia total [as N]									
	1 - Effluent Gross	Smpl.								
	Season: 0	Req.								
	NODI: <input type="checkbox"/>	NODI								

Code	Parameter Name	NODI	Quantity or Loading		Quality or Concentration		Units	# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2	Value 1	Value 2				
50050	Flow, in conduit or thru treatment plant	Smpl.					MGD			
1 - Effluent Gross										
Season: 0		Req.	Req Mon Daily Average	Req Mon Daily Maximum			Million Gallons per Day			TOTAL
NODI: [v]		NODI	[C]	[C]			MGD			
50050	Flow, in conduit or thru treatment plant	Smpl.					MGD			
Y - Effluent Gross (Supplementary)										
Season: 0		Req.	<= 46 Annual Average				Million Gallons per Day		Monthly	TOTAL
NODI: [v]		NODI	[C]							
50060	Chlorine, total residual	Smpl.								
A - Disinfection, Process Complete										
Season: 0		Req.			< .1 Instantaneous Maximum		mg/L		Daily	GRAB
NODI: [v]		NODI			[C]					
50060	Chlorine, total residual	Smpl.					mg/L			
B - Prior to Disinfection										
Season: 0		Req.					Milligrams per Liter		Daily	GRAB
NODI: [v]		NODI								
51040	E. coli	Smpl.					mg/L			
1 - Effluent Gross										
Season: 0		Req.					Milligrams per Liter		Daily	GRAB
NODI: [v]		NODI								
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.					CFU/100mL			
1 - Effluent Gross										
Season: 0		Req.					Colony Forming Units per 100ml		Five Per Week	GRAB
NODI: [v]		NODI								
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.					mg/L			
1 - Effluent Gross										
Season: 0		Req.	<= 3836 Daily Average				Milligrams per Liter		Daily	COMPOS
NODI: [v]		NODI	[C]							

Collapse Header

Permit TX0077801

Permit ID: SAN ANTONIO WATER SYSTEM

Permittee: DOS RIOS WATER RECYCLING CTR.

Facility: 101 - Internal Outfall

Permitted Feature: From 06/01/18 to 06/30/18

Report Dates & Status: NetDMR Validated

Monitoring Period:

Status:

Principal Executive Officer:

First Name: Parviz

Title: Sr. Director

No Data Indicator (NODI):

Form NODI:

Major:

Permittee Address: 2800 US HIGHWAY 281 NORTH
SAN ANTONIO, TX 78212
3495 VALLEY RD.
SAN ANTONIO, TX 78221
A - DOMESTIC WASTEWATER - 101

Facility Location:

Discharge:

DMR Due Date: 07/20/18

Last Name: Chavol

Telephone: 210-233-3239

Parameter Code	Name	NODI	Value 1	Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Quality or Concentration	Smpl. Type
50050	Flow, in conduit or thru treatment plant	Smpl.	5.71	0.07		MGD	0	99/99		TM
	1 - Effluent Gross									
Season: 0										TOTALZ
NODI: <input type="checkbox"/>										
50050	Flow, in conduit or thru treatment plant	Smpl.	5.87			MGD	0	99/99		TM
Y - Effluent Gross (Supplementary)										
Season: 0										TOTALZ
NODI: <input type="checkbox"/>										

Edit DMR

102

Collapse Header

Permit

Permit ID: TX0077801

Permittee: SAN ANTONIO WATER SYSTEM

Facility: DOS RIOS WATER RECYCLING CTR.

Permitted Feature: 102 - Internal Outfall

Report Dates & Status

Monitoring Period: From 06/01/18 to 06/30/18

Status: NetDMR Validated

Principal Executive Officer

First Name: Parviz

Title: Sr. Director

No Data Indicator (NODI)

Form NODI:

Major: 2800 US HIGHWAY 281 NORTH
Permittee Address: SAN ANTONIO, TX 78212
 3495 VALLEY RD.
Facility Location: SAN ANTONIO, TX 78221
Discharge: A - TOTAL DISCHARGE - 001 & 101
DMR Due Date: 07/20/18

Last Name: Chavol
Telephone: 210-233-3239

Code	Parameter Name	NODI	Value 1	Value 2	Units
------	----------------	------	---------	---------	-------

50050 Flow, in conduit or thru treatment plant

Smpl.

Season: 0

Req. Req Mon Daily Average

Req Mon Daily Maximum

Value 1

Value 2

Quality or Concentration

Value 3

Units

Smpl. Type

Freq. of Analysis

of Ex.

NODI:

50050 Flow, in conduit or thru treatment plant

Smpl.

Season: 0

Req. <= 125 Annual Average

Million Gallons per Day

Value 1

Quality or Concentration

Value 3

Units

Smpl. Type

Freq. of Analysis

of Ex.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-033	02	18	06	12647
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR COMBINED MONITORING for 001/800/900 DOS RIOS
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE			
	REPORTED	PERMITTED			VALUE	UNITS		
500507124 FLOW DLY AVG	REPORTED	PERMITTED	0	02	90.24	MGD	11	
				02			CONT	CONT
500507128 FLOW ANN AVG	REPORTED	PERMITTED	0	02	89.44	MGD	11	
				02			CONT	CONT
NUMBER OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01	WW0013780	NUMBER	NA	
				01			NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01	07/15/2019	DATE	NA	
				01			NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	0	01	A	LETTER	NA	
				01			NA	NA
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						
	REPORTED	PERMITTED						

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.

	NAME	SIGNATURE	DATE
	Tad Eaton Manager-Prod & Treat Ops		18 07 11
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
2 1 0 2 3 3 3 2 3 9	Parviz Chaval Sr. Director		18 07 11
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-033	02	18	06	12551
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE I DOS RIOS
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE		
	REPORTED	PERMITTED			VALUE	UNITS	NO.
000085342 TRANSFER DAYS/MON	REPORTED	PERMITTED	19	DAY	0 01	01	
					01	NA	01 NA
316164024 E-COLI DLY AVG	REPORTED	PERMITTED	1.27	#/100 ML	0 11	03	
			20.000		11	2/WEEK	03 GRABPKLOAD
316164030 E-COLI IND GRAB	REPORTED	PERMITTED	10.00	#/100 ML	0 11	03	
			75.000		11	2/WEEK	03 GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	PERMITTED	1.98	MGD	0 02	11	
					02	CONT	11 CONT
500507128 FLOW ANN AVG	REPORTED	PERMITTED	1.66	MGD	0 02	11	
					02	CONT	11 CONT
800821024 BOD CARB DLY AVG	REPORTED	PERMITTED	2.05	MG/L	0 08	1/Day	10 12-PRT-COM
			5.000		11	2/WEEK	03 GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED	PERMITTED	1.17	NTU	0 08	1/Day	10 12-PRT-COM
			3.000		11	2/WEEK	03 GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	WW0013780	NUMBER	0 01	NA	
					01	01	NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	07/15/2019	DATE	0 01	NA	
					01	01	NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	A	LETTER	0 01	NA	
					01	01	NA NA
	REPORTED	PERMITTED					

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.	NAME Tad Eaton Manager-Prod & Treat Ops	SIGNATURE 	DATE 11 8 07 11
TELEPHONE NUMBER 2 1 0 2 3 3 3 2 3 9	PLANT OPERATOR Parviz Chavol Sr. Director	PLANT OPERATOR 	YEAR MO. DAY 11 8 07 11
AREA CODE NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-033	02	18	06	12552
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE II DOS RIOS
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	PERMITTED		VALUE	UNITS		
000085342 TRANSFER DAYS/MON	REPORTED	PERMITTED	0				
				DAY	01	NA	01 NA
316164024 FEC. COLI DLY AVG	REPORTED	PERMITTED					
				#/100 ML	14	1/WEEK	03 GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	PERMITTED					
				#/100 ML	14	1/WEEK	03 GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	PERMITTED					
				MGD	02	CONT	11 CONT
500507128 FLOW ANN AVG	REPORTED	PERMITTED					
				MGD	02	CONT	11 CONT
800821024 BOD CARB DLY AVG	REPORTED	PERMITTED					
				MG/L	14	1/WEEK	03 GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	WW0013780	NUMBER	0 01		NA
					01 01		NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	07/15/2019	DATE	0 01		NA
					01 01		NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	A	LETTER	0 01		NA
					01 01		NA NA
	REPORTED	PERMITTED					
	REPORTED	PERMITTED					

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.	NAME	SIGNATURE	DATE
	Tad Eaton Manager-Prod & Treat Ops		18 07 18
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
2 1 0 2 3 3 3 2 3 9	Parviz Chavol Sr. Director		18 07 17
AREA CODE NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

OVERFLOW REPORT

PERIOD: JUNE 2018

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	527104	2324700	6/17/2018	Elm Valley Dr	5700	1,275 Grease	Cleaned Main	0.85	0.65	Drainage Culvert	Area Cleaned and Disinfected. Flushed Area with H2O Returned To System
	525813	2302210	6/1/2018	Northwestern Dr	3215	78,063 Debris	Cleaned Main	4.94	1.33	Ground - Spilled Into Huebner Creek	Flushed Area with H2O Clean Up Is Ongoing, Warning Signs Were Posted
Total Events:					2	Total Gallons:	79,338	Average Duration:	2.90	Average Response	

Thursday, July 05, 2018

Note: Comments reflect status reported on the 5-Day report

[Edit DMR](#)

Collapse Header

Permit

Permit ID: TX0052639

Permittee: SAN ANTONIO WATER SYSTEM

Facility: LEON CREEK WATER RECYCLING CENTER

Permitted Feature: 001 - External Outfall

Report Dates & Status: From 06/01/18 to 06/30/18

Monitoring Period: NetDMR Validated

Status: NetDMR Validated

Principal Executive Officer: Parviz

First Name: Sr. Director

Title: [Empty]

No Data Indicator (NODI): [Empty]

Form NODI: [Empty]

Major:

Permitted Address: 2800 US HWY 281 NORTH

Facility Location: SAN ANTONIO, TX 78212

Discharge: 1104 MAURERMAN ROAD

DMR Due Date: SAN ANTONIO, TX 78224

DMR Due Date: A - DOMESTIC FACILITY - 001

DMR Due Date: 07/20/18

Last Name: Chavol

Telephone: 210-233-3239

001

Showing Parameters 1 - 10 of 13

Parameter Code	Name	NODI	Value 1	Units	Quantity or Loading	Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
00300	Oxygen, dissolved [DO]		= 5.3					mg/L	1	01/01	GR
1 - Effluent Gross								Milligrams per Liter		Daily	GRAB
Season: 0											
NODI: [Empty]											
00400	pH		= 6.3					SU	1	01/01	GR
1 - Effluent Gross								Standard Units		Daily	GRAB
Season: 0											
NODI: [Empty]											
00530	Solids, total suspended		= 1.16					mg/L	1	01/01	CP
1 - Effluent Gross								Milligrams per Liter		Daily	COMPOS
Season: 0											
NODI: [Empty]											

Parameter Code	Parameter Name	NODI	Value 1	Quantity or Loading Value 2	Units	Value 1	Quality or Concentration Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
00610	Nitrogen, ammonia total [as N]		[v] 66		lb/d		[v] 4	[v] 1.12	mg/L	0	01/01	CP
1 - Effluent Gross												
Season: 0		Req.	<= 767 Daily Average		Pounds per Day		<= 2 Daily Average	<= 7 Daily Maximum	Milligrams per Liter		Daily	COMPOS
NODI: [v]		NODI	[v]				[v]	[v]				
00940	Chloride [as Cl]		[v] 36,298		lb/d		[v] 71	[v] 78	mg/L	0	01/01	CP
1 - Effluent Gross												
Season: 0		Req.	Req Mon Daily Average		Pounds per Day		Req Mon Daily Average	Req Mon Daily Maximum	Milligrams per Liter		Daily	COMPOS
NODI: [v]		NODI	[v]				[v]	[v]				
50050	Flow, in conduit or thru treatment plant		[v] 25.45	[v] 30.78	MGD					0	9999	TM
1 - Effluent Gross												
Season: 0		Req.	Req Mon Daily Average	Req Mon Daily Maximum	Million Gallons per Day						Continuous	TOTAL
NODI: [v]		NODI	[v]	[v]								
50050	Flow, in conduit or thru treatment plant		[v] 27.778		gal/min					0	9999	TM
P - See Comments												
Season: 0		Req.	<= 6.3889 2 Hour Peak		Gallons per Minute						Continuous	TOTAL
NODI: [v]		NODI	[v]	[v]								
50050	Flow, in conduit or thru treatment plant		[v] 31.43		MGD					0	9999	TM
Y - Effluent Gross (Supplementary)												
Season: 0		Req.	<= 46 Annual Average		Million Gallons per Day						Continuous	TOTAL
NODI: [v]		NODI	[v]	[v]								
50060	Chlorine, total residual							[v] 0.08	mg/L	0	01/01	GR
A - Disinfection, Process Complete												
Season: 0		Req.						< .1 Instantaneous Maximum	Milligrams per Liter		Daily	GRAB
NODI: [v]		NODI	[v]	[v]			[v]	[v]				
50060	Chlorine, total residual									0	01/01	GR
B - Prior to Disinfection												
Season: 0		Req.	>= 1 Monthly Minimum						Milligrams per Liter		Daily	GRAB
NODI: [v]		NODI	[v]	[v]								

601

Edit DMR

Collapse Header

Permit

Permit ID: TX0052639
Permittee: SAN ANTONIO WATER SYSTEM

Facility: LEON CREEK WATER RECYCLING CENTER

Permitted Feature:

001 - External Outfall

Report Dates & Status

Monitoring Period: From 06/01/18 to 06/30/18
Status: NetDMR Validated

Principal Executive Officer

First Name: Parviz
Title: Sr. Director

No Data Indicator (NODI)

Form NODI:

Major: 2800 US HWY 281 NORTH
Permittee Address: SAN ANTONIO, TX 78212
 1104 MAURMAN ROAD
Facility Location: SAN ANTONIO, TX 78224
Discharge: A - DOMESTIC FACILITY - 001
DMR Due Date: 07/20/18
Last Name: Chavol
Telephone: 210-233-3239

Showing Parameters 11 - 13 of 13

Code	Parameter Name	NODI	Quantity or Loading			Quality or Concentration			# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2	Units	Value 1	Value 2	Value 3			
51040	E. coli	Smpl.									
1 - Effluent Gross											
Season: 0		Req.									
NODI: <input type="text" value=""/>		NODI									
70295	Solids, total dissolved	Smpl.	<input type="text" value="1748460"/>								
1 - Effluent Gross											
Season: 0		Req.									
NODI: <input type="text" value=""/>		NODI									
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.	<input type="text" value="125"/>								
1 - Effluent Gross											
Season: 0		Req.									
NODI: <input type="text" value=""/>		NODI									

[Edit DMR](#)

Collapse Header

Permit

Permit ID: TX0052639

Permittee: SAN ANTONIO WATER SYSTEM

Facility: LEON CREEK WATER RECYCLING CENTER

Permitted Feature: 002 - External Outfall

Report Dates & Status: From 06/01/18 to 06/30/18

Monitoring Period: NetDMR Validated

Status: NetDMR Validated

Principal Executive Officer: Parviz

First Name: Sr. Director

Title: [Empty]

No Data Indicator (NODI) Form NODI: [Empty]

Major:

Permitted Address: 2800 US HWY 281 NORTH
SAN ANTONIO, TX 78212
1104 MAURERMAN ROAD
SAN ANTONIO, TX 78224
A - DOMESTIC FACILITY - 002

Facility Location: [Empty]

Discharged: [Empty]

DMR Due Date: 07/20/18

Last Name: Chavol

Telephone: 210-233-3239

002

Showing Parameters 1 - 10 of 11

Code	Name	NODI	Value 1	Value 2	Units	Quality or Concentration	Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
00300	Oxygen, dissolved [DO]		[5.3]						mg/L	0	01/01	GR
1 - Effluent Gross												
Season: 0												
NODI: [5.3]												
00400	pH		[6.8]						Milligrams per Liter	0	01/01	GRAB
1 - Effluent Gross												
Season: 0												
NODI: [6.8]												
00530	Solids, total suspended		[1.85]						Standard Units	0	01/01	GR
1 - Effluent Gross												
Season: 0												
NODI: [1.85]												
00610	Nitrogen, ammonia total [as N]		[0.71]						mg/L	0	01/01	CP
1 - Effluent Gross												
Season: 0												
NODI: [0.71]												
00700	Ammonia, total		[0.87]						mg/L	0	01/01	CP
1 - Effluent Gross												
Season: 0												
NODI: [0.87]												

Parameter Code	Parameter Name	NODI	Quantity or Loading		Quality or Concentration		# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2	Value 1	Value 2			
50050	Flow, in conduit or thru treatment plant								
	1 - Effluent Gross	Smpl.	=	0.21			0	99/99	TM
	Req. Mon Daily Average	Req.			Req Mon Daily Maximum			Continuous	TOTALZ
	NODI	NODI							
50050	Flow, in conduit or thru treatment plant								
	P - See Comments	Smpl.		0.650			0	99/99	TM
	Req. Mon Daily Average	Req.			Req Mon Daily Maximum			Continuous	TOTALZ
	NODI	NODI							
50050	Flow, in conduit or thru treatment plant								
	Y - Effluent Gross (Supplementary)	Smpl.		0.24			0	99/99	TM
	Req. <= 46 Annual Average	Req.						Continuous	TOTALZ
	NODI	NODI							
50060	Chlorine, total residual								
	A - Disinfection, Process Complete	Smpl.					0	01/01	GR
	Req. < .1 Instantaneous Maximum	Req.					0	01/01	GRAB
	NODI	NODI							
50060	Chlorine, total residual								
	B - Prior to Disinfection	Smpl.		0.02			0	01/01	GR
	Req. >= 1 Monthly Minimum	Req.					0	01/01	GRAB
	NODI	NODI							
51040	E. coli								
	1 - Effluent Gross	Smpl.					0	07AWK	GR
	Req. <= 126 Daily Average	Req.					0	07AWK	GRAB
	NODI	NODI							



101

Collapse Header

Permit

Permit ID: TX0052639

Permittee: SAN ANTONIO WATER SYSTEM

Facility: LEON CREEK WATER RECYCLING CENTER

Permitted Feature: 101 - External Outfall

Report Dates & Status: From 06/01/18 to 06/30/18

Monitoring Period: NetDMR Validated

Status:

Principal Executive Officer

First Name: Parviz

Title: Sr. Director

No Data Indicator (NODI)

Form NODI:

Major:

Permitted Address: 2800 US HWY 281 NORTH

Facility Location: SAN ANTONIO, TX 78212
1104 MAUERMAN ROAD

Discharge: SAN ANTONIO, TX 78224
A - COMBINED OUTFALLS 001 & 002

DMR Due Date: 07/20/18

Last Name: Chaval

Telephone: 210-233-3239

Code	Parameter Name	NODI	Value 1	Quantity or Loading Value 2	Units	Value 1	Quality or Concentration Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
00530	Solids, total suspended		747		lb/d					0	01/01	CP
	J - Intermediate Treatment, Process Complete				Pounds per Day						Daily	COMPOS
Season: 0												
NODI:												
00610	Nitrogen, ammonia total [as N]		87		lb/d					0	01/01	CP
	J - Intermediate Treatment, Process Complete				Pounds per Day						Daily	COMPOS
Season: 0												
NODI:												
50050	Flow, in conduit or thru treatment plant		25.52	30.92	MGD					0	99/99	TM
	1 - Effluent Gross				Million Gallons per Day						Continuous	TOTALZ
Season: 0												
NODI:												
50050	Flow, in conduit or thru treatment plant		27778		gal/min					0	99/99	TM
	P - See Comments				Gallons per Minute						Continuous	TOTALZ
Season: 0												
NODI:												

Parameter	NODI	Value 1	Quantity or Loading	Units	Value 1	Quality or Concentration	Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
Code Names												
50050 Flow, in conduit or thru treatment plant		31.5		MGD						0	99/99	TM
Y - Effluent Gross (Supplementary)				Million Gallons per Day								
Season: 0		<= 46 Annual Average										TOTALZ
NODI: [v]												
80082 BOD, carbonaceous [5 day, 20 C]		128		lb/d						0	01/01	CP
J - Intermediate Treatment, Process Complete				Pounds per Day								COMPOS
Season: 0		<= 2686 Daily Average										
NODI: [v]												

Edit Check Errors

No results.

DMR Comments

THE COMBINED FLOW FOR OUTFALLS 001 AND 002 SHALL NOT EXCEED 46 MGD AND 2-HR PEAK OF 63889 GPM. POUNDS PER DAY LOADING SHALL ALSO BE THE COMBINED TOATL OF BOTH OUTFALLS

Comments

Attachments

No results.

Report Last Saved By

User: FloramieWelch
 Name: Floramie Welch
 E-Mail: floramie.welch@saws.org
 Date/Time: 07/13/18 1:27 CDT

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-003	02	18	06	12645
SYS	PERMIT NUMBER	SET	YEAR	MO	EID

THIS REPORT TO BE USED FOR COMBINED MON 189 for 001/002/800/900 LEON CREEK

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		VALUE	UNITS				
500507124 FLOW	REPORTED	32.31	MGD	0	02	11	
DLY AVG	PERMITTED				02	CONT	11
500507128 FLOW	REPORTED	33.95	MGD	0	02	11	
ANN AVG	PERMITTED				02	CONT	11
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0004506	NUMBER	0	01	NA	
	PERMITTED				01	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	01/08/2020	DATE	0	01	NA	
	PERMITTED				01	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01	NA	
	PERMITTED				01	01	NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.	NAME	SIGNATURE	DATE
	Daniel Rodriguez Manager Prod & Treat Ops		18 07 12
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
210 233 3239	Parviz Chavol Senior Director		18 07 12
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-003	02	18	06	12547
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE I 800 LEON CREEK
 SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	PERMITTED		VALUE	UNITS		
000085342 TRANSFER DAYS/MON	REPORTED	PERMITTED	30	DAY	0 01	01	
					01	NA	01 NA
316164024 E-COLI DLY AVG	REPORTED	PERMITTED	1.00	#/100 ML	0 11		03
			20.000		11	2/WEEK	03 GRABPKLOAD
316164030 E-COLI IND GRAB	REPORTED	PERMITTED	1.00	#/100 ML	0 11		03
			75.000		11	2/WEEK	03 GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	PERMITTED	6.79	MGD	0 02		11
					02	CONT	11 CONT
500507128 FLOW ANN AVG	REPORTED	PERMITTED	2.46	MGD	0 02		11
					02	CONT	11 CONT
800821024 BOD CARB DLY AVG	REPORTED	PERMITTED	2.00	MG/L	0 08	1/Day	10 12-prt-com
			5.000		11	2/WEEK	03 GRABPKLOAD
820786624 TURBDITY 30DAY AV	REPORTED	PERMITTED	0.68	NTU	0 08	1/Day	10 12-prt-com
			3.000		11	2/WEEK	03 GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	WW0004506	NUMBER	0 01		NA
					01	01	NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	01/08/2020	DATE	0 01		NA
					01	01	NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	PERMITTED	A	LETTER	0 01		NA
					01	01	NA NA
	REPORTED	PERMITTED					

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.	NAME Daniel Rodriguez Manager Prod & Treat Ops	SIGNATURE 	DATE 18 07 17
TELEPHONE NUMBER 210 233 3239	PLANT OPERATOR Parviz Chavol Senior Director	PLANT OPERATOR 	YEAR MO. DAY 18 07 17
AREA CODE 210	NUMBER 233 3239	EXECUTIVE OFFICER Parviz Chavol	EXECUTIVE OFFICER

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3495 VALLEY RD
SAN ANTONIO TX 78221-5238



40B	WQ0010137-003	02	18	06	12548
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR [RECLAIMED WATER TYPE II 900 LEON CREEK]
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	REPORTED	PERMITTED			VALUE	UNITS
000085342 TRANSFER DAYS/MON	REPORTED		0	01	0	01
	PERMITTED				01	NA
316164024 FEC. COLI DLY AVG	REPORTED					
	PERMITTED		200.000		14	1/WEEK
316164030 FEC. COLI IND GRAB	REPORTED					
	PERMITTED		800.000		14	1/WEEK
500507124 FLOW DLY AVG	REPORTED					
	PERMITTED				02	CONT
500507128 FLOW ANN AVG	REPORTED					
	PERMITTED				02	CONT
800821024 BOD CARB DLY AVG	REPORTED					
	PERMITTED		15.000		14	1/WEEK
NUMBER OF OPERATOR CERTIFICATE	REPORTED		WW0004506		0	01
	PERMITTED				01	01
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		01/08/2020		0	01
	PERMITTED				01	01
CLASS OF OPERATOR CERTIFICATE	REPORTED		A		0	01
	PERMITTED				01	01
	REPORTED					
	PERMITTED					
	REPORTED					
	PERMITTED					

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.

	NAME	SIGNATURE	DATE
	Daniel Rodriguez Manager Prod & Treat Ops		18 07 17
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
2 1 0 2 3 3 3 2 3 9	Parviz Chavol Senior Director		18 07 18
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR MO. DAY

OVERFLOW REPORT

PERIOD:

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Gallons:											
Average Duration:											
Average Response											

Thursday, July 05, 2018

Note: Comments reflect status reported on the 5-Day report

Edit DMR

Collapse Header

Permit

Permit ID:

Permittees:

Facility:

Permitted Feature:

Report Dates & Status

Monitoring Period:

Status:

Principal Executive Officer

First Name:

Title:

No Data Indicator (NODI)

Form NODI:

TX0055689

SAN ANTONIO WATER SYSTEM

MEDIO CREEK WATER RECYC. CTR.

001 - External Outfall

From 06/01/18 to 06/30/18

NetDMR Validated

Parviz

Sr. Director

Major:

Permittee Address:

Facility Location:

Discharge:

DMR Due Date:

Last Name:

Telephone:

2800 US HWY 281 NORTH

SAN ANTONIO, TX 78245

2231 HUNT LANE

SAN ANTONIO, TX 78227

B - DOMESTIC FACILITY - 001

07/20/18

Chavol

210-233-3239

Parameter Code	Name	NODI	Value 1	Quantity or Loading Value 2	Units	Value 1	Quality or Concentration Value 2	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
00300	Oxygen, dissolved [DO]					>= 5.72			mg/L	0	01/01	GR
	1 - Effluent Gross	Smpl.							Milligrams per Liter		Daily	GRAB
	Season: 0	Req.				>= 6 Monthly Minimum						
	NODI:	NODI										
00400	pH					>= 7.18			SU	0	01/01	GR
	1 - Effluent Gross	Smpl.							Standard Units		Daily	GRAB
	Season: 0	Req.				>= 6 Minimum						
	NODI:	NODI										
00530	Solids, total suspended								mg/L	0	01/01	CP
	1 - Effluent Gross	Smpl.							Milligrams per Liter		Daily	COMPOS
	Season: 0	Req.				<= 2002 Daily Average						
	NODI:	NODI										
00610	Nitrogen, ammonia total [as N]								mg/L	0	01/01	CP
	1 - Effluent Gross	Smpl.							Milligrams per Liter		Daily	COMPOS
	Season: 0	Req.				<= 267 Daily Average						
	NODI:	NODI										

Parameter Code	Name	NODI	Value 1	Quantity or Loading	Value 2	Units	Value 1	Value 2	Quality or Concentration	Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
50050	Flow, in conduit or thru treatment plant	Smpl.	= 5.58	= 5.81	MGD							0	99/99	TM
1 - Effluent Gross														
Season: 0		Req.	Req Mon Daily Average	Req Mon Daily Maximum	Millions Gallons per Day								Continuous	TOTAL
NODI:		NODI										0	99/99	TM
50050	Flow, in conduit or thru treatment plant	Smpl.	= 101		gal/min							0	99/99	TM
P - See Comments														
Season: 0		Req.		<= 27778 2 Hour Peak	Gallons per Minute								Continuous	TOTAL
NODI:		NODI										0	99/99	TM
50050	Flow, in conduit or thru treatment plant	Smpl.	= 106		MGD							0	99/99	TM
Y - Effluent Gross (Supplementary)														
Season: 0		Req.	<= 16 Annual Average		Millions Gallons per Day								Continuous	TOTAL
NODI:		NODI										0	01/01	GR
51040	E. coli	Smpl.			lb/d							0	01/01	GR
1 - Effluent Gross														
Season: 0		Req.		<= 7 Daily Average	Pounds per Day								Daily	GRAB
NODI:		NODI										0	01/01	CP
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.	= 30		mg/L							0	01/01	CP
1 - Effluent Gross														
Season: 0		Req.	<= 934 Daily Average		Milligrams per Liter								Daily	COMPOS
NODI:		NODI										0		

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3225 VALLEY RD
SAN ANTONIO TX 78221-5201



40B	WQ0010137-040	01	18	06	12654
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR COMBINED MON 189 for 001/800/900 MEDIO CREEK
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	REPORTED	PERMITTED				
500507124 FLOW	REPORTED	6.07	0	02	11	
DLY AVG	PERMITTED			02	CONT	CONT
500507128 FLOW	REPORTED	6.24	0	02	11	
ANN AVG	PERMITTED			02	CONT	CONT
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0004506	0	01	NA	
	PERMITTED			01	01	NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	01/08/2020	0	01	NA	
	PERMITTED			01	01	NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	0	01	NA	
	PERMITTED			01	01	NA NA
	REPORTED					
	PERMITTED					
	REPORTED					
	PERMITTED					
	REPORTED					
	PERMITTED					
	REPORTED					
	PERMITTED					
	REPORTED					
	PERMITTED					

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.	NAME	SIGNATURE	DATE
	Daniel Rodriguez Manager-Prod & Treat Ops		18 07 17
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
2 1 0 2 3 3 3 2 3 9	Parviz Chavol Senior Director		18 07 17
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3225 VALLEY RD
SAN ANTONIO TX 78221-5201



40B	WQ0010137-040	01	18	06	12553
SYS	PERMIT NUMBER	SET T	YEAR MO.		EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE | 800 MEDIO CREEK
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS. **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE				
	REPORTED	PERMITTED			VALUE	UNITS	NO.	TYPE	
000085342 TRANSFER DAYS/MON	REPORTED		29	DAY	0	01	01		
	PERMITTED					01	NA	01	NA
316164024 FEC. COLI DLY AVG	REPORTED		1.09	#/100 ML	0	11		03	
	PERMITTED		20.000			11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED		2.00	#/100 ML	0	11		03	
	PERMITTED		75.000			11	2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED		2.58	MGD	0	02		11	
	PERMITTED					02	CONT	11	CONT
500507128 FLOW ANN AVG	REPORTED		2.21	MGD	0	02		11	
	PERMITTED					02	CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED		2.00	MG/L	0	08	1/Day	10	12-prt-com
	PERMITTED		5.000			11	2/WEEK	03	GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED		0.61	NTU	0	08	1/Day	10	12-prt-com
	PERMITTED		3.000			11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED		WW0004506	NUMBER	0	01		NA	
	PERMITTED					01	01	NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		01/08/2020	DATE	0	01		NA	
	PERMITTED					01	01	NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		A	LETTER	0	01		NA	
	PERMITTED					01	01	NA	NA
	REPORTED								
	PERMITTED								

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.	NAME	SIGNATURE	DATE
	Daniel Rodriguez Manager-Prod & Treat Ops		11/8/97/117
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
210 233 3239	Parviz Chavol Senior Director		11/8/07/117
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT



PAGE 1

SAN ANTONIO WATER SYSTEM
3225 VALLEY RD
SAN ANTONIO TX 78221-5201



40B	WQ0010137-040	02	18	06	12554
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR RECLAIMED WATER TYPE II 900 MEDIO CREEK
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS.
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS.

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	PERMITTED		VALUE	UNITS		
000085342 TRANSFER DAYS/MON	REPORTED		0	01		01	
	PERMITTED			01	NA	01	NA
316164024 FEC. COLI DLY AVG	REPORTED						
	PERMITTED		200.000		14 1/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED						
	PERMITTED		800.000		14 1/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED						
	PERMITTED				02 CONT	11	CONT
500507128 FLOW ANN AVG	REPORTED						
	PERMITTED				02 CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED						
	PERMITTED		20.000		14 1/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED		WW0004506	0	01		NA
	PERMITTED				01 01		NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		01/08/2020	0	01		NA
	PERMITTED				01 01		NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		A	0	01		NA
	PERMITTED				01 01		NA NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.	NAME	SIGNATURE	DATE
	Daniel Rodriguez Manager-Prod & Treat Ops		11/8/07/17
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
2 1 0 2 3 3 3 2 3 9	Parviz Chavol Senior Director		11 8 07 17
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR MO. DAY

Edit DMR

Collapse Header

Permit TX0065641 Major: 2800 US HWY 281 NORTH

Permittee: SAN ANTONIO WATER SYSTEM **Permittee Address:** SAN ANTONIO, TX 782982449
10762 PLEASANTON RD

Facility: MITCHELL LAKE WWTF **Facility Location:** SAN ANTONIO, TX 78212
A - DOMESTIC FACILITY - 001

Permitted Feature: 001 - External Outfall **Discharge:**

Report Dates & Status From 06/01/18 to 06/30/18 **DMR Due Date:** 07/25/18

Monitoring Period: NetDMR Validated

Status:

Principal Executive Officer

First Name: Parviz **Last Name:** Chavol

Title: Sr. Director **Telephone:** 210-233-3239

No Data Indicator (NODI) Form NODI:

Parameter Code	Name	NODI	Quantity or Loading Value 1	Units	Value 2	Quality or Concentration Value 3	Units	# of Ex.	Freq. of Analysis	Smpl. Type
00300	Oxygen, dissolved [DO]	Smpl.	>= 4 Monthly Minimum				mg/L		Daily	GRAB
1 - Effluent Gross										
Season:	0									
NODI:										
00310	BOD, 5-day, 20 deg. C	Smpl.					mg/L		Daily	GRAB
1 - Effluent Gross										
Season:	0									
NODI:										
00400	pH	Smpl.					SU		Monthly	GRAB
1 - Effluent Gross										
Season:	0									
NODI:										

Parameter Code	Name	NODI	Quantity or Loading		Quality or Concentration		# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2	Value 1	Value 2			
00530	Solids, total suspended	Smpl.							
	1 - Effluent Gross								
Season: 0		Req.							
NODI:		NODI							
50050	Flow, in conduit or thru treatment plant	Smpl.							
	1 - Effluent Gross								
Season: 0		Req.							
NODI:		NODI							
51040	E. coli	Smpl.							
	1 - Effluent Gross								
Season: 0		Req.							
NODI:		NODI							

Edit Check Errors

No results.

DMR Comments

MONITORING SHALL OCCUR WHEN DISCHARGING. SAMPLES FOR BACTERIA MONITORING SHALL BE TAKEN AT THE INFLOW PIPE FROM THE ELEON CREEK WRC.

Comments

Attachments

No results.

Report Last Saved By

User: FloramieWelch
 Name: Floramie Welch
 E-Mail: floramie.welch@saws.org
 Date/Time: 07/13/18 12:56 CDT



[View All Copies of Submissions](#) | [DMR/COR Search Results](#) | [View DMR Signing Status](#)

Signing Process Confirmation - CDX Activity ID: _d1feeaf0-5dd9-4398-8b4c-11f4d792f105

Your DMRs are undergoing the Signing Process

<u>Permit ID</u>	<u>Facility</u>	<u>Permitted Feature</u>	<u>Discharge #</u>	<u>Discharge Description</u>	<u>Monitoring Period End Date</u>	<u>DMR Due Date</u>	<u>View Copy of Submission</u>
TX0052639	LEON CREEK WATER RECYCLING CENTER	001	001-A	DOMESTIC FACILITY - 001	06/30/18	07/20/18	
TX0052639	LEON CREEK WATER RECYCLING CENTER	002	002-A	DOMESTIC FACILITY - 002	06/30/18	07/20/18	
TX0052639	LEON CREEK WATER RECYCLING CENTER	101	101-A	COMBINED OUTFALLS 001 & 002	06/30/18	07/20/18	
TX0055689	MEDIO CREEK WATER RECYC. CTR.	001	001-B	DOMESTIC FACILITY - 001	06/30/18	07/20/18	
TX0065641	MITCHELL LAKE WWTF	001	001-A	DOMESTIC FACILITY - 001	06/30/18	07/25/18	
TX0077801	DOS RIOS WATER RECYCLING CTR.	001	001-A	DOMESTIC FACILITY - 001	06/30/18	07/20/18	
TX0077801	DOS RIOS WATER RECYCLING CTR.	002	002-A	DOMESTIC FACILITY - 002	06/30/18	07/20/18	
TX0077801	DOS RIOS WATER RECYCLING CTR.	003	003-A	DOMESTIC FACILITY - 003	06/30/18	07/20/18	
TX0077801	DOS RIOS WATER RECYCLING CTR.	004	004-A	DOMESTIC FACILITY - 004	06/30/18	07/20/18	
TX0077801	DOS RIOS WATER RECYCLING CTR.	005	005-A	DOMESTIC FACILITY - 005	06/30/18	07/20/18	
TX0077801	DOS RIOS WATER RECYCLING CTR.	006	006-A	DOMESTIC FACILITY - 006	06/30/18	07/20/18	
TX0077801	DOS RIOS WATER RECYCLING CTR.	101	101-A	DOMESTIC WASTEWATER - 101	06/30/18	07/20/18	
TX0077801	DOS RIOS WATER RECYCLING CTR.	102	102-A	TOTAL DISCHARGE - 001 & 101	06/30/18	07/20/18	
TX0125083	SAN ANTONIO WATER SYSTEM PORTABLE WTP	001	001-A	WATER TREATMENT WASTES - 001	06/30/18	07/20/18	

2078 NetDMR